We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists



186,000

200M



Our authors are among the

TOP 1% most cited scientists





WEB OF SCIENCE

Selection of our books indexed in the Book Citation Index in Web of Science™ Core Collection (BKCI)

# Interested in publishing with us? Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected. For more information visit www.intechopen.com



# **Conventional Media Filtration with Biological Activities**



Additional information is available at the end of the chapter

http://dx.doi.org/10.5772/50481

# 1. Introduction

Conventional gravity filtration takes advantage of gravity of water as a driving force, and is classified as slow media filtration or rapid media filtration. A slow sand filter is simple in design, construction, and operation. It is simply a filter box (usually made of concrete) containing sand media supported by a layer of gravel with appurtenances to deliver and remove water. The first recorded use of slow sand filters for a citywide water supply was in 1804 by John Gibbs in Paisley, Scotland (Barrett et al. 1991). Slow sand filters as their name implies, is accomplished with a relatively slow speed of filtration (typically 0.1 to 0.2 meters per hour) with 1 to 2 meters media depth. Because of the slow filtration rate, the head loss buildup is gradual and usually takes several months to achieve a significant level and form a condensed layer called *schmutzdecke* on media surface, which will be removed manually with media replenishment. Therefore the filter runtime is usually in the magnitude of months as opposed to 24-48 hours with rapid sand filters. A rapid sand filter is operated in a much higher speed (typically 2 to 10 meters per hour) with periodically backwashing the filter to recover headloss which builds up much faster due to a higher filtration speed. Backwashing is initiated normally by set time intervals, headloss across a filter media bed, or filter effluent turbidity. For both slow and rapid filters, filter run times are highly dependent on the freeboard on the top of the media. The freeboard is 1-3 meters, designed according to water qualities, especially turbidity and total suspended solids.

Sand, anthracite, and granular activated carbon or their combination was used as media with proper gradation. Some proprietary media as pumice, expanded clay, diatomaceous earth, and ceramic have also been applied. Characteristics of different media are shown in Table 1.

When media becomes clogged and dirty, the best way is to backwash the filter and flush dirt out. Backwash is classified as fluidized backwash and sub-fluidized backwash. Fluidized backwash requires a higher water rate to expand media bed usually by 20-30%, where the minimal fluidization water velocity is directly related to media type, media size, uniformity



coefficient, water temperature, and salinity (important factor for sea water filtration) (Logsdon et al. 2002). However, a fluidization test is always recommended for precisely identifying the backwash rate to achieve the desired fluidization. Usually sub-fluidized backwash is applied to coarse media with 15-20 m/h, where media will only move or rotate locally and expand slightly as fluidization of larger media require an extremely high water velocity (Logsdon et al. 2002). Backwash can be water only backwash or air assisted backwash, the later of which has gained popularity because of water conservation and effectiveness of media cleaning. The air scouring (usually at 70-90 m/h) can be before water wash, after water wash, simultaneously with water, or combination thereof. Logsdon et al. (2000) summarized the typical water and air rates for backwashing filters with different types of media.

With concurrent air scouring and water wash, the filter bed undergoes a "collapse pulsing action" under optimal air and water rates, which can be predicted according to a set of empirical equations applicable to different media gradation and water temperature (Amirtharajah 1993). Obtaining and sustaining collapse pulse action within the backwashing process is optimum for the removal of particles from the media grains. The collapse pulsing action can be described as follows: the air bubble exits the air delivery device (orifice) and expands under the weight of the media. When the air bubble expands, the media expands slightly within the vicinity of the bubble, and the bubble collapses and reforms just above its original location. This collapsing is due to the weight of the media. The bubble reforms above its original location because the media is only partially expanded. Just prior to collapsing, high local water velocities occur at the perimeter of the bubble. Simultaneous to bubble collapse, media particles rush together and collide in a violent scouring action. This creates a "pulsation" in the bed. The bubble travels on upward, expands, collapses, and reforms again, and repeats the process several times as it passes through the bed.

Media	Density	Major Constituents	Specific Surface Area (SSA) and its		
	(g/cm <sup>3</sup> )		References		
			SSA (BET) (m <sup>2</sup> /g)	References	
Garnet	3.6-4.2	Nesosilicates		(Logsdon et al. 2002)	
Sand	2.6	SiO <sub>2</sub>	0.04 ±0.001 (0.25 and	(Jerez et al. 2006)	
			0.5 mm size)	(a)	
Anthracite	1.6	Carbon	6-7 (0.2-0.4 mm size)	(Davidson et al. 1996)	
GAC	1.3-1.5	Carbon	720 (<1 mm size)	(Gergova et al. 1993)	
			900 (0.149 mm size)	(Oliveira et al. 2002)	
			928 (0.15 and 0.25 mm	(Tang et al. 2004)	
			size)		
Diatomaceous	1.0-1.6	SiO2, Al2O3, Fe2O3	27.8 (106–250 mm	(Al-Ghouti et al. 2003)	
earth			size)		
Expanded clay	1.0-1.6	SiO2, Al2O3, Fe2O3	398 (10-100 µm size)	(Occelli et al. 2002)	
Pumice	0.4	Highly vesicular	2.1-14.2 (<63-1000 μm	(Kitis et al. 2007)	
		texture glass	size)		

 Table 1. Characteristics of different media used for water filtration



Figure 1. Sketch of typical nozzle design on a filter floor

To fully clean the filter media without forming dead zones, mud balls, media encrustation, and boiled media spots, even distribution of air and water during backwashing is critical. Fundamentally, there are two types of designs for simultaneous air and water distribution, nozzles and underdrain (with integrated dual channels). Nozzles (Figure 1) usually have slot sizes in the range 0.25–0.5 mm to minimize the risk of sand penetration. Nozzle arrangement density on the floor depends on the type of nozzles and is greater than about 35 nozzles/m<sup>2</sup> (Ratnayaka et al. 2009). However, the design of nozzle slots needs to be considered carefully to prevent fouling. There are several other underdrain systems, mostly of proprietary designs, successfully used in many parts of the world. An example is the design by Leopold (a Xylem brand) which comprises underdrain blocks (each block approximately 1 foot ×1 foot ×4 feet), formed from high-density polyethylene (HDPE), which snap lock together to form water resistant long laterals (Figure 2). The blocks incorporate a dual lateral design with a water recovery channel that ensures uniform distribution of concurrent air and water even over laterals up to 42 feet or 12.8 m. The blocks can be fitted with a porous HDPE IMS<sup>®</sup> Cap on top that helps to eliminate the need for support gravel (Figure 2).



Figure 2. Sketch of typical underdrain design with dual channels (courtesy of Leopold, a Xylem brand)

### 2. Filtration with biological activity

Biological water and wastewater treatment processes are based on the growth of microbial communities capable of metabolizing contaminants through mediating oxidation-reduction reactions. The oxidants (electron acceptors) are normally oxygen, nitrate, perchlorate, sulfate, and Fe (III); the reductants (electron donors) are normally organic matter, trace organic compounds, ammonia, As (III), and iron (II) and Mn (II), etc. In a fixed-film biological process, biofilms are developed on media such as sand, anthracite, granular activated carbon (GAC), or membranes. A biofilm process mainly consists of two simultaneous steps, substrate diffusion and biological reaction, as illustrated in Figure 3. Electron donors and acceptors diffuse from bulk fluid into the biofilm and are metabolized by microbial cells in the biofilm, as a result of which the diffusion profiles are parabolic.



**Z** Direction

Figure 3. Schematic diagram of substrate diffusion in a biofilm attached to a solid substratum

Biologically active filters (BAFs) are essentially of the same physical structures as rapid gravity filters except BAFs are maximized with biological activities without backwashing the filters with chlorinated water or with no pre-chlorination. BAFs have been used for decades in North America and Europe in drinking water treatment, but have drawn more attention only recently. Regulatory and customer acceptance remain an issue because of the concern of microbial sloughing and breakthrough. A recent survey conducted by the AWWA Research Foundation indicated that 44% of the respondents believed biological processes in the drinking water industry were not accepted and 25% believed they were. Major operational concerns were breakthrough of pathogens and sloughing of bacteria (Evans et al. 2008). However, coliform bacteria were rarely observed in BAF effluents in laboratory studies, indicating that coliform organisms were eliminated by the microbial activity in the filters because of the competition for limited nutrients (Camper et al. 1985; Rollingger and Dott 1987). A pilot study demonstrated that biologically active filters reduced microbial activities in distribution systems (Characklis 1988). Furthermore, French experience indicated that removal of biodegradable materials resulted in a lesser amount of

microbial presence in the distributions systems (Bourbigot et al. 1982). Comparison of physicochemical and biological treatments indicated that biological treatment limited mutagenic generation (Carraro et al. 2000).

# 3. Applications and design parameters

Perhaps, slow sand filters (SSFs) were the earliest application of a biological process in drinking water treatment. The major function of a filter occurs at the surface layer (Schmutzdecke) of the sand bed which contains a zoogeal jelly in which biological activities are highest (Babbitt and Doland 1939). Full scale experience indicated NOM removal was 15±5 mg/L by slow sand filters (Collins et al. 1992). Coliform reduction was 2-4 log (Barrett et al. 1991), and E Coli reduction was found strongly correlated with carbon dioxide respiration in the top 2.5 cm media and protistan abundance in the top 0.5 cm Schmutzdecke (Unger and Collins 2008). With over 150 years of history, river bank filtration (RBF) showed efficient organic substance removal in full scale plants in the Netherlands and Germany (Piet and Zoeteman 1980; Sontheimer 1980). River bank filtration removed TOC by 33-86% and disinfection by-product formation potential by 30-100% at the wells in several drinking water utilities in the US (Partinoudi and Collions 2007; Weiss et al. 2003).

A previous review of biological processes in drinking water treatment summarized that a wide range of contaminants can be removed through biological oxidation and reduction of dissolved constituents including natural organic matter (NOM), ammonia, nitrate, perchlorate, and iron and manganese, where operating parameters were discussed (Bouwer and Crowe 1988). Additionally, BAFs were reported to remove trace organic compounds, halogenated organics, perchlorate, and arsenic. A BAF usually does not require the addition of other chemicals for oxidizing and removing of contaminants. It does not require close monitoring of a breakthrough point, as in conventional column adsorption processes. Some organics adsorbed in activated carbon particles can be degraded by microorganisms attached on the activated carbon, or through enzymatic reaction during normal operation and hence create some active adsorption sites (Perrotti et al. 1974; Rice and Robson 1982; Rodman et al. 1978). This process is referred as biological regeneration. The service life of activated carbon can be extended by biologically regenerating exhausted carbon. The treated water from the BAF is unlikely to produce undesirable disinfection by-products and bacteria re-growth in the water distribution system (Dussert and Van Stone 1994; Scholz and Martin 1997).

#### 3.1. Removal of natural organic matter (NOM)

Natural organic matter (NOM), consisting of humic acid, fulvic acid, carbohydrates, and other natural compounds, is present in natural water sources and is a precursor of disinfection by products (DBPs). DBPs are compounds formed when strong oxidants such as chlorine and ozone come into contact with NOM. Epidemiological evidences supported an association between chlorinated water or trihalomethanes and bladder cancer (Cantor et al. 1987; Cantor et al. 1999; Doyle et al. 1997). The most prevalent DPBs that form as a result of contact between organic carbon and chlorine include total trihalomethanes (TTHMs) and

haloacetic acids (HAA5). To mitigate public exposure to these compounds, US Environment Protection Agency (EPA) has developed regulations restricting their concentrations at all points in the distribution system. The initial legislation formed for these restrictions is known as Stage 1 Disinfectants and Disinfection Byproducts Rule. A secondary stage for the DBP rule had also been promulgated by EPA in 2006. Stage 2 Disinfectants and Disinfections Byproducts Rule was applied as an addition to the continual improvement of safety in drinking water standards in the United States. Amendments to Stage 1 DBP rule include: (a) requiring annual averages at every point in the distribution system to adhere to the predefined maximum contamination levels (MCLs), (b) escalating the sampling frequency for communities with larger populations, and (c) the utility's distribution system must be evaluated to identify locations with elevated DBP concentrations.

To remove DBP precursors, biologically active filtration using different media was employed worldwide, usually assisted by pre-ozonation which increased assimilable organic carbon (AOC) or biodegradable organic matter (BOM) which was subsequently metabolized by biofilms in biofilters (Carlson and Amy 2001; Goel et al. 1995; Weiss et al. 2003). The design parameters are empty bed contact time (EBCT), media selection, media configuration, backwash regime selection, temperature in addition to pre-ozone doses. A summary of design parameters and media selection and observations in previous studies were provided in Table 2. Majority of the studies showed that an EBCT of 10 minutes should be used in process design to achieve 30-50% TOC removal with GAC. When combined with pre-ozonation, an EBCT of 5 minutes appeared sufficient (Hozalski et al. 1995; Laurent et al. 1999; Rittmann et al. 2002; Weiss et al. 2003).

The design of biologically active filters should be based on the achievement of one of the following criteria:

- Maximal removal of DOC to reduce the formation of DBPs;
- Maximal removal of BOM to minimize the risk of biological re-growth in the distribution system;
- Maximal removal of potential carcinogenic ozonated by-products (OBPs) such as formaldehyde.

Direct comparison showed that the GAC/sand filter produced better performance than the anthracite/sand filter (Rittmann et al. 2002) and the GAC/Sand filter out performed anthracite/sand filter by 11% for AOC removal (Weiss et al. 2003). GAC media showed better resistance to temperature at 1-3 °C in terms of oxalate and TOC removal compared with anthracite (Emelko et al. 2006). The BOM (10% acetate and 90% other organic matter with a maximal degradation rate less than one-tenth that of acetate) removal was reduced from 55% at 22.5 °C to 12% at 6 °C in a sand filter at EBCT 7.5 minutes (Hozalski et al. 1999).

Emelko et al. (2006) studied the effect of backwash and temperature on full scale biofiltration, and concluded that biodegradable organic material (BOM) removal was not influenced by backwash regimes even though some biomass expressed by phospholipid was lost during backwash with air scouring. Others also concluded that backwashing did not

have noticeable impact on BOM removal because no more than 25% of biomass was washed out (Hozalski et al. 1999; Rittmann et al. 2002). However, microbial communities in the filters and during the operating condition shifts were not investigated in this study. In another study, it was found that backwashing caused changes in the relative compositions of microorganisms in a GAC biofilm in the top layer of the bed and reduced the attached bacterial abundance to 64% (Kasuga et al. 2007). The relative abundances of some terminal-restriction fragments (T-RFs) increased such as the *Planctomycetes*-derived fragment; however, some decreased, which included the  $\beta$ -proteobacteria-derived fragments (Kasuga et al. 2007).

Nutrient levels were also shown to influence the process efficiency. In a full scale study at Daugava water treatment plant in Riga, Latvia, the process including ozonation and biofiltration was not efficient for removal of dissolved organic carbon (DOC) from waters with a high amount of humic substances likely due to phosphorus limitation (Juhna and Rubulis 2004).

Phosphorus supplementation in a pilot study decreased biofilter terminal headloss by ~15 percent relative to the control likely the result of reduced EPS formation in the filter, and decreased contaminant breakthrough relative to the control biofilter, including MIB (~75 percent less breakthrough), manganese (~90 percent less breakthrough), and DOC (~15 percent less breakthrough) (Lauderdale et al. 2011).

Study Scales	Parameters	Findings	References
Pilot using filters	GAC/sand filter:	Pre-ozonation increased	(Weiss et al. 2003)
of granular	EBCT 5 minutes with 29%	Assimilable Organic	
activated carbon	TOC removal; EBCT 10	Carbon (AOC) in influent,	
(GAC),	minutes with 33% TOC	but also increased BAF	
GAC/sand,	removal; EBCT 15 minutes	effluent AOC relative to	
anthracite/sand	with 42% TOC removal;	non-ozonated influent	
	EBCT 20 minutes with	water. GAC/Sand filter	
	51% TOC removal	was better than	
	0.3-1.0 mg O₃/mg	anthracite/sand filter by	
	TOC	11% for AOC	
		removal.	
IRWD pilot	EBCT from 3.5 to 9	Up to 90% of color was	(Rittmann et al.
facility in Santa	minutes	removed and up to 38%	2002)
Ana, California,	1.0-1.8 g O <sub>3</sub> /g TOC	DOC was removed;	
including BAF		GAC biofilter gave better	
following		performance than	
ozonation.		anthracite.	
Laboratory-scale	0-7.3 mg O <sub>3</sub> /mg TOC	Biodegradability of four	(Goel et al. 1995)
batch		NOM sources was	
degradation		improved by ozonation in	
tests		the range of 0-7.3 mg	

Study Scales	Parameters	Findings	References
Laboratory-scale	EBCT from 4 to 20 minutes 2-4 mg O3/mg TOC	O3/mg TOC. Degradation of high molecular weight organics were more influenced by ozonation Ozonated NOM removal was significantly affected	(Hozalski et al. 1995)
active sand (ES 0.5 mm) filters.		by the sources of the organic carbon independent of EBCT	
Laboratory-scale biodegradability study with Ohio River	0.6-1.0 mg O3/mg TOC (optimal for DBP reduction) 2.0 mg O3/mg TOC (maximal for AOC)		(Shukairy et al. 1992)
Laboratory-scale biologically active glass beads and sand (ES 0.52 mm) filters.	EBCT 7.5 minutes 0.58±0.12 mg O₃/mg TOC	30% TOC removal was achieved. Perfromance was not impaired by backwash.	(Hozalski et al. 1999)
Pilot including biologically active filters (expanded clay 0.5-2.5 mm) following ozonation.	EBCT 11-54 minutes 1.0-1.7 mg O <sub>3</sub> /mg TOC	EBCT did not have a significant impact; TOC removal 18-37% ; majority (80%) of BOM were removed;	(Melin and Odegaard 1999)
Full scale GAC filters at River dune Water Works	EBCT 20 minutes with two stages 0.35-0.45 mg O3/mg TOC	50% TOC removal; successive reactivation of GAC was still effective	(van der Hoek et al. 1999)
Full scale BAC filters, St-Rose Treatment plant, Canada	EBCT 5-12 minutes	50% BDOC removal	(Laurent et al. 1999)

Study Scales	Parameters	Findings	References
Lab scale	2 mg O <sub>3</sub> /mg TOC	40-50% DOC removal	(Siddiqui et al.
biodegradability		40-60% THMFP removal	1997)
study		90-100% aldehydes	
		removal	
Pilot including	0.6 mg O <sub>3</sub> /mg DOC	Maximal 9% DOC was	
biologically	EBCT 2-11 minutes	removed at EBCT 15	
active anthracite		minutes with 5 m/h and	$\frown$
filters following		EBCT 7 minutes with 9.7	$\overline{}$
ozonation.		m/h;	
		80% ozone by-products	
		were removed at EBCT 3-5	
		minutes	
Lab scale	EBCT 20 minutes	45% BDOC removal	(Yavich and
fluidized GAC	1 mg O3/mg TOC		Masten 2003)
filter			
Pilot including	0.6 mg O <sub>3</sub> /mg DOC	Up to 1.0 mg O <sub>3</sub> /mg DOC	(Carlson and Amy
biologically	EBCT 6 minutes	produced maximal	2001)
active anthracite	Temperature 6-10 ⁰C	BDOCrapid/DOC; and 0.4-	
filters following		0.6 mg O3/mg DOC	
ozonation.		produced maximal	
		BDOCrapid/BDOCtotal.	
		Cumulative 90% DOC	
		removal at EBCT 6	
		minutes.	
Pilot including	EBCT 5 minutes	7-9% TOC (as UV254)	(Chaiket et al.
anthracite and	0.5-1.0 mg O <sub>3</sub> /mg DOC	removal;	2002)
GAC filters		No difference was	
directly		observed between GAC	
following		and anthracite filters due	-
ozonation.		to the nature of the water	
Full scale	EBCT 10-60 minutes	10-50% DOC removal; no	(Najm et al. 2005)
including GAC	0.5-2 mg O <sub>3</sub> /mg DOC	significant difference	
filters directly		between lignite and	
following		bituminous GAC.	
ozonation at			
Sweeney WTP,			
vvilmington,			
NC.			

**Table 2.** Design parameters and findings for the removal of natural organic matter removal (NOM) in previous studies

#### 3.2. Removal of MIB and geosmin

The presence of tastes and odors in drinking water is an increasing and serious problem in the United States and the world. Some species of algae and bacteria naturally produce odorous chemicals inside their cells. Geosmin (trans-1, 10-dimethyl-trans-9-decalol) and MIB (2-methylisoborneol) are common odorous chemicals. There are no maximal contamination levels (MCLs) for MIB and Geosmin in drinking water systems according to US EPA. However, earthy and musty odors generated by Geosmin and MIB are detectable by individuals at the concentrations of 5 to 10 parts per trillion, and often result in customer complain. When large numbers of algae and bacteria flourish in a water body (an "algae bloom"), taste and odor-compound concentrations increase to levels above this threshold and cause taste and odor problems.

Biological active filtration was effectively used for the removal of Geosmin and MIB as summarized in Table 3. Since the concentrations of Geosmin and MIB encountered in drinking water systems are usually much less than that of TOC, a secondary utilization pathway was proposed as opposed to primary substrate utilization (Bouwer and Crowe 1988). Primary substrates support steady state biofilms which in turn metabolize secondary substrates such as Geosmin and MIB.

Unlike the removal of TOC, placing ozonation in front of GAC filters was not benefiting the removal of MIB and Geosmin likely due to the competition from increased AOC (Vik et al. 1988). An important design parameter is EBCT, which is usually in the range of 5-20 minutes depending on the required removal. GAC filters provided resistance to temperature variation while the removal was reduced by 24% for both Geosmin and MIB when temperature was reduced from 20 to 8°C in anthracite filters (Elhadi et al. 2006). At lower temperatures (6-12 °C), MIB and Geosmin removal was also reduced with expanded clay by 15% and 10%, respectively, compared to that at 15 °C (Persson et al. 2007). Biodegradation of both MIB and Geosmin was determined to be a pseudo-first-order reaction, with rates influenced by the initial amount of the biofilm biomass (Ho et al. 2007). As a result, sand with a well-established biofilm taken from a 26 years old filter was capable of removing MIB and Geosmin to below detection limits after 11 days of operation while sand without an established biofilm removed 60% Geosmin and 40% MIB after 154 days of operation (McDowall et al. 2007). Four bacteria, a Pseudomonas sp., an Alphaproteobacterium, a Sphingomonas sp. and an Acidobacteriaceae member were identified as microorganisms most likely involved in the biodegradation of Geosmin within the sand filters (Ho et al. 2007).

Study Scales	Parameters	Findings	References
Full scale study at	0.66-0.81 mg	Ozonation removed 36-65% MIB	(Nerenberg et
CLCJAWA Water	O3/mg TOC	and biofiltration removed 26-46%	al. 2000)
Treatment Plant at	EBCT 10-20	of MIB. The biodegradability of	
Lake Bluff, Illinois,	minutes	geosmin and MIB was confirmed	
which included		by a bench scale study, where 55%	
biologically active		and 44% removal was achieved for	
GAC filters		geosmin and MIB, respectively.	
following ozonation.			

Study Scales	Parameters	Findings	References
Pilot study of sand	EBCT 5 minutes	11 to 38%	(Ndiongue et
filters capped with		700/	al. 2006)
CAC Coordin was	EBC1 7.5 minutes	78% geosmin removal; Geosmin	
GAC. Geosmin was		was better removed than MIB.	
In the range of about			
70 to 110 ng/L,		7(1-1000/	(F11 1 1 1
Bench-scale two 2.0	EBCI 5.6 minutes	76 to 100% geosmin removal and	(Elhadi et al.
m nign glass	1 emperature 12-	47% to 100% MIB removal.	2004)
GAC/sand filters	16 .	The exhausted GAC initially	
		heat the new seed is more and with,	
		but the removals increased over	
D 1 1			/E11 1 / 1
Bench-scale	EBC1 5.6 minutes	60% geosmin and 40% MIB	(Elhadi et al.
GAC/sand and	1 emperature 8	removal at 20 °C in GAC filters.	2006)
anthracite/sand	and 20 °C	36% geosmin and 16% MIB	
filters		removal at 8 °C in anthracite	
		filters.	
Bench-scale sand	EBCT 15 minutes	60% geosmin and 40% MIB with	(McDowall et
filters		new sand after 154 days; reduced	al. 2007)
		to below detection limit with sand	
		from a 26 years old filter with a	
		well-established biofilm	
Pilot study of GAC	EBCT 6, 15 and 30	Exhausted GAC had adsorption	(Persson et al.
and expanded clay	minutes	capability for MIB and Geosmin.	2007)
filters		At initial 20 ng/L MIB and 20 ng/L	
		Geosmin:	
		97% removal at 30 minutes EBCT;	
		90% removal at 15 minutes EBCT;	
		>40% remocal at 6 minutes EBCT	
Bench-scale sand	EBCT 15 minutes	95% removal of both MIB and	(Ho et al. 2007)
filters	20±2 °C	geosmin with sand from	
		an over 30 year	
		facility	
Pilot GAC and	EBCT 21 minutes	TOC removal was better with	(Vik et al.
ozone plus GAC	2-5 O₃ mg/L	ozone plus GAC;	1988)
	1.5-4 TOC mg/L	GAC was better for MIB and	
		geosmin removal than ozone plus	
		GAC because of the competition of	
		TOC. GAC kept Geosmin	
		and MIB below 10 ng/L	

Table 3. Design parameters and findings for the removal of MIB and Geosmin in previous studies

#### 3.3. Removal of iron, manganese, and arsenic

Appreciable amounts of iron and manganese usually exist in ground water or lake water experiencing low dissolved oxygen levels. The US EPA set secondary MCLs for iron and manganese at 0.3 mg/L and 0.05 mg/L, respectively.

There are two valences of iron and manganese, Fe (II) and Fe (III); Mn (II) and Mn (IV). Fe (II) and Mn (II) are quite soluble than Fe (III) and Mn (IV), respectively. As summarized in a previous study, the solubility product of ferrous hydroxide was in the range of  $7 \times 10^{-13}$  to  $4.5 \times 10^{-21}$  while the solubility product of ferric hydroxide was  $3 \times 10^{-38}$  to  $4 \times 10^{-36}$  (Gayer and Woontner 1956). The solubility product of manganous hydroxide was  $9.0 \times 10^{-14}$  and manganese dioxide was in equilibrium with Mn(OH)<sub>4</sub> (aq) with an equilibrium constant of  $4.0 \times 10^{-5}$  (Swain et al. 1975). Mn(OH)<sub>4</sub> (aq) will be prone to adsorption during filtration. Therefore, media filtration will not be effective to remove total iron and manganese if considerable portions are at the lower valance. Physicochemical removal requires a strong oxidant injected in front of media filtration to oxidize lower valance metals to a higher valance (Equations 1 and 2) and then filtered out.

$$2Fe^{2+} + 3/2O_2 = Fe_2O_3 \tag{1}$$

$$Mn^{2+} + O_2 = MnO_2$$
 (2)

Fe (II) and Mn (II) can provide energy as electron donors for autotrophic biological reactions when oxygen is present. Biological filtration was demonstrated effective for iron and manganese removal assisted with aeration or ozonation in front of filtration (Table 4). It appeared that EBCT of 10 minutes reduced iron and manganese by 95-100% with coarse or fine sand media (Katsoyiannis and Zouboulis 2004; Lytle et al. 2007a; Štembal et al. 2005; Tekerlekopoulou et al. 2008). The use of ozone was beneficial (Pokhrel et al. 2005), but it appeared that aeration was sufficient for providing oxygen (Katsoyiannis and Zouboulis 2004; Lytle et al. 2007a; Štembal et al. 2005).

Arsenic is a semi-metal element in the periodic table. It is odorless and tasteless. It enters drinking water supplies from natural deposits in the earth or from agricultural and industrial practices. Non-cancer effects can include thickening and discoloration of the skin, stomach pain, nausea, vomiting; diarrhea; numbness in hands and feet; partial paralysis; and blindness. Arsenic has been linked to cancer of the bladder, lungs, skin, kidney, nasal passages, liver, and prostate. US EPA set the arsenic standard for drinking water at 0.01 mg/L (10 parts per billion or ppb) to protect consumers served by public water systems subject to the effects of long-term, chronic exposure to arsenic.

Understanding the oxidation state is important for arsenic removal from drinking water. There are two oxidation states for arsenic: arsenite (As (III)) and arsenate (As (V)). Arsenite typically forms aqueous As(OH)<sub>3</sub>, As(OH)<sub>4</sub><sup>-</sup>, and AsO<sub>2</sub>OH<sup>2-</sup>, depending on pH; dissolved arsenate forms AsO<sub>4</sub><sup>3-</sup>, HAsO<sub>4</sub><sup>2-</sup>, or H<sub>2</sub>AsO<sub>4</sub><sup>-</sup> (Edwards 1994; Katsoyiannis et al. 2002). At 6.9 < pH < 11.5, HAsO<sub>4</sub><sup>2-</sup> is the primary species; and at 2.2 < pH < 6.9, H<sub>2</sub>AsO<sub>4</sub><sup>-</sup> is the primary arsenate species (Edwards 1994; Katsoyiannis et al. 2002). Arsenate adsorbs to soil minerals, particularly iron oxides and hydroxides. Arsenate sorption to iron oxides peaks around pH

5-7. Arsenite tends to adsorb less strongly than arsenate. Source water containing arsenite generally requires using a strong oxidant, e.g., chlorine, chlorine dioxide, and ozone, to oxidize arsenite to arsenate which can be removed by coagulation and filtration. Arsenic (V) removal by either ferric chloride or alum was relatively insensitive to variations in source water composition below pH 8 meanwhile arsenic (III) removal by ferric chloride was less efficient and more strongly influenced by source water composition than arsenic(V) removal (Hering et al. 1997). The presence of sulfate (at pH 4 and 5) and natural organic matter (at pH 4 through 9) adversely affected the efficiency of arsenic (III) removal by ferric chloride and arsenic(III) could not even be removed by coagulation with alum (Hering et al. 1997).

Study Scales	Water Qualities	Parameters	Findings	References
Pilot GAC	Fe 6.4-8.4 mg/L	EBCT 34.1	The biologically active	(Pokhrel et al.
column with	Mn 0.93-0.99	minutes	system removed 99.8%	2005)
1740 mm	mg/L	6.2-8.5 O <sub>3</sub>	of Fe(II), and with the	
(height) by 450	As 14.5-27.3 μg/L	mg/L	ozone pretreatment, the	
mm	DOC 4.3-4.9		average removal	
(diameter)	mg/L		increased to 99.9% for Fe(II).	
Pilot study of	Fe 0.09-0.44	EBCT 30 and	Iron and manganese	(Pacini et al.
roughing filter	mg/L	60 minutes	removal efficiencies	2005)
with gravel	Mn 0.18-1.83	(roughing	were between 85% and	
and sand filter	mg/L	filter)	95%.	
		EBCT 5		
		minutes		
		(sand filter)		
Pilot filter (1	Fe 2.8 mg/L	EBCT 7.3	Fe(II) was	(Katsoyiannis
m high		minutes	microbiologically	and Zouboulis
polystyrene			oxidized to Fe(III)	2004)
Beads 3-4 mm)			precipitated on the filter	
			bed.	
Bench-scale	Mn 0.86-1.83		90% Mn removal	(Burger et al.
sand filter	mg/L			2008)
Pilot trickling	Mn 0.6-2.0 mg/I	EBCT 9	Close to 100% Mn	(Tekerlekopoulou
filter (1.9 mm	Will 0.0–2.0 Ilig/L	minutes	removal	et al. 2008)
sand)				
Pilot sand	Fe 0-2.45 mg/L	EBCT 4.75-	95% Fe, Mn, and NH4-N	(Štembal et al.
filter (190 cm	Mn 0.1-1.06 mg/L	10.4 minutes	removal	2005)
high, 0.5-2.0	NH4-N 0.02-2.62			
mm sand)	mg/L			
Pilot dual	As 37±2 μg/L	EBCT 9.4	Reduced Fe to less than	(Lytle et al.
media filter	NH4-N 1.15	minutes	25 μg/L	2007a)
(20" anthracite	mg/L			
over 10" sand)	Fe 2289 ±114 µg/L			

Table 4. Design parameters and findings for the removal of iron and manganese in previous studies

Study scale dual	Water	Parameters	Findings	References
media filters at	Qualities			
Pilot dual media	As 37±2 μg/L	EBCT 9.4 minutes	Reduced to less than	(Lytle et al.
filter (20"	NH4-N 1.15		10 μg/L;	2007a)
anthracite over	mg/L		Majority of As in the	
10" sand)	Fe 2289 ±114		effluent was	
	μg/L		particular.	
Pilot	As 20-46 μg/L	EBCT 10 minutes	Reduced to less than	(Lytle et al.
anthracite/sand			10 μg/L	2007b)
filters				
Pilot GAC column	Fe 6.4-8.4 mg/L	EBCT 34.1	97% without	(Pokhrel et al.
with 1740 mm	Mn 0.93-0.99	minutes	ozonation; 99% with	2005)
(Height) by 450	mg/L	6.2-8.5 O₃ mg/L	pre-ozonation	
mm (Diameter).	As 14.5-27.3			
	μg/L			
	DOC 4.3-4.9			
	mg/L			
Pilot filter (1 m	As 50–200 μg/L	EBCT 7.3 minutes	Reduced to less	(Katsoyiannis
high polystyrene			than 10 μg/L	and Zouboulis
Beads 3-4 mm)				2004)
Pilot filter (1 m	As 40–50 μg/L	EBCT 7.3 minutes	80% As removal	(Katsoyiannis
high polystyrene	DO 2.7 mg/L			et al. 2002)
Beads 3-4 mm)				
Pilot filter with at	As(III) 30-200	EBCT 7.9 minutes	95% As removal	(Liu et al. 2010)
least 0. 66 m sand	μg/L			
	Fe(II) 0.5-1.5			
	mg/L			
	Mn(II) 0.6-2.0			
	mg/L			
Pilot slow sand	As 50 μg/L	EBCT 4-5 hours		(Gottinger
filter (sand 0.45-		0.023 m/h	filtration sand only	2010)
0.55 mm mixed			removed As <11%;	
with iron fillings)			all iron/sand	
			columns achieved	
			greater than 92%	
Pilot clow cond	$\Lambda_{c} = 10^{-25} \cdots \alpha^{T}$	FRCT 1 25 hours	Reduced to less them	(Pokhrol and
filter (90 cm cond	As $10-55 \mu\text{g/L}$	EDC1 4.25 Hours	E ug/L if Eo/As food	(FORITEI and
0.25-2 mm			ratio was 10	2009)
Pilot CAC filtor	$\Delta s(III) 25 m c^{/I}$	FBCT 6 bours	$\sim 100 \text{ was } 40$	(Mondal of al
(100  cm CAC 2.4)	$F_{\rho}(II) = 10 \text{ mg/L}$		80% Fo removal	2008)
(100  cm, GAC  2-4)	Mn(II) 2 mg/I		95% Mn removal	2000)
	1 $1$ $1$ $1$ $1$ $1$ $1$ $1$ $1$ $1$	1	75 /o IVIII TEIIIOVAI	

**Table 5.** Design parameters and findings for the removal of arsenic in previous studies

The current treatment options include activated alumina, iron oxide coated sand, greensand, reverse osmosis, ion exchange, and electrodialysis in addition to coagulation (Edwards 1994).

Similar to Fe (II) and Mn (II), arsenite can provide energy as an electron donor for autotrophic biological reactions when oxygen is present. Biological filtration was shown effective for arsenite removal assisted with aeration or ozonation in front of filtration (Table 5). Various media including sand, anthracite, GAC, and polystyrene beads were used for arsenic removal. Generally an EBCT of 10 minutes is required to reduce arsenic from up to 100  $\mu$ g/L down to less than 10  $\mu$ g/L. Due to the strong affinity of arsenate to ferric oxide, feeding ferric in the influent increased the removal efficiency with an increasing Fe/As ratio (Pokhrel and Viraraghavan 2009). A study found filtration columns containing mixture of sand and iron fillings improved removal and were capable of reducing arsenic from 50 to well below 10 $\mu$ g/L with an average of 92% removal (Gottinger 2010).

To improve the removal efficiency, immobilizing whole bacterial cells has attracted more research interest in recent years. *Ralstonia eutropha MTCC 2487* (this strain can produce ArsR protein and arsenate reductase enzyme) was immobilized on GAC bed in the column reactor (Mondal et al. 2008). *D. Desulfuricans, G. ferrigunea, L. ocracia, R. picketti, T. ynys1, Gallionella,* and *Leptothrix* were exploited to remove arsenic in biofiltration columns (Brunet et al. 2002; Elliot et al. 1998; Jong and Pany 2003; Katsoyiannis et al. 2002).

### 3.4. Removal of ammonia (nitrification)

Although there is no ammonia drinking water standard in the United States, the European community has established a maximum limit of approximately 0.5 mg/L and a guide level of 0.05 mg/L (EU Council 1980). Although there are no immediate indications that ammonia will become regulated within the United States, there are benefits for utilities to reduce the amount of ammonia that is able to enter a distribution system. The presence of ammonia in drinking water distribution systems has been correlated to increased biological activity, corrosion, formation of nitrite and nitrates, and adverse impacts on taste and odor (AWWA 2006). In addition, the presence of ammonia can interfere with the effectiveness of some water treatment processes including biological manganese removal as ammonia removal must be achieved before manganese removal due to the fact that the oxidation potential for nitrification is lower than manganese oxidation (McGovern and Nagy 2010).

Nitrification can be achieved in different ways, but may be most cost effectively accomplished by employing biofiltration (Table 6). The effectiveness of biological ammonia oxidation treatment to reduce source water ammonia levels is dependent on a number of source water and engineering design factors including temperature, dissolved oxygen, TOC, pH, biomass quantity and population, media type, and surface area, as well as hydraulic loading rate and contact time (Zhang et al. 2009). Factors affecting nitrification occurrence, nitrification impacts on water quality and corrosion, and nitrification monitoring and control methods were reviewed previously (Zhang et al. 2009). Arrhenius coefficient was

1.12 without acclimation and 1.06 with acclimation (Andersson et al. 2001). At temperature less than 4 °C, nitrification seemed un-sustained and feeding low temperature culture (psychrophiles) seemed necessary (Andersson et al. 2001). However, in fixed-film biofilters, the impact of temperature on nitrification rate was less significant than that predicted by the van't Hoff-Arrhenius equation, and a temperature increment at 20 °C resulted in a nitrification rate increase of 1.108% per degree and 4.275% per degree under DO and ammonia limiting conditions, respectively (Zhu and Chen 2002).

Study Scales	Water Qualities	Parameters	Findings	References
Pilot sand filter	Fe 0-2.45 mg/L	EBCT 4.75-10.4	95% Fe, Mn, and	(Štembal et al.
(190 cm high,	Mn 0.1-1.06	minutes	NH4-N removal	2005)
0.5-2.0 mm	mg/L			
sand)	NH4-N 0.02-2.62			
	mg/L			
Full scale and	$NH_4-N < 1 mg/L$	EBCT up to 28	EBCT 5 minutes	(Andersson et
pilot scale GAC		minutes	seems suitable for	al. 2001)
filters at St			removing ammonia;	
Rose WTP at				
Laval, Canada				
Pilot gravel	$NH_4-N < 1 mg/L$	EBCT 4-23 minutes	70-80% at EBCT 7.8	(Forster 1974)
filter (180 cm	26 °C		minutes;	
high, 6-12 mm			>90% at EBCT 10	
and 12-25 mm			minutes	
gravel)				
Pilot aerated	NH4-N 2.88	EBCT 10 minutes	95% ammonia	(Rogalla et al.
GAC filter (85	mg/L		removal	1990)
cm high)				
Pilot dual	NH4-N <1.7	EBCT 9.4 minutes	Close to 100%	(Lytle et al.
media filter	mg/L		ammonia removal	2007a)
(20" anthracite				
over 10″	$1 \Gamma ( \bigtriangleup ) ($		$  \rangle    \cap \langle ( -$	
sand)			レハワハロ	711

Table 6. Design parameters and findings for the removal of ammonia in previous studies

European experience on nitrification was reviewed for trickling filters, up-flow fluidized bed filters, rapid sand filters, and GAC filters (Rittmann and Snoeyink 1984). In a pilot trickling filter operated at 2.4 m/h with 2 m gravel media, ammonia removal was 80% at 20 °C; 78% at 15 °C; 67% at 10 °C; and 50% at 5 °C. In fluidized filters, nearly 100% removal was achieved as long as the fluidized solids were at least 30% by volume from 4-20 °C. Nearly 100% nitrification was achieved using rapid sand filters at Mulheim where raw water contained 1 mg/L ammonia nitrogen. Complete nitrification was achieved with GAC filters at 10 m/h with an EBCT of 10 minutes.



**Figure 4.** Phylogenetic tree of AOB based on multiple alignment of 55 nearly full-length AOB 16S rDNA sequences. Abbreviations are Nm for *Nitrosomonas*, Nc for *Nitrosococcus*, and Ns for *Nitrosospira*. *R. eutropha* is a non-AOB member of the *Betaproteobacteria* subphylum. Scale bar represents 10% sequence difference (Regan 2001)

Nitrification is a two-step process: ammonia oxidation and nitrite oxidation. The bacterial genera associated with ammonia oxidation are named as ammonia oxidizing bacteria (AOB) and the bacterial genera associated with nitrite oxidation are named as nitrite oxidizing bacteria (NOB). Both AOB and NOB are autotrophic bacteria using carbon dioxide for cellular synthesis under aerobic conditions. Phylogenetic trees for AOB and NOB were summarized elsewhere (Regan 2001) as shown in Figures 4 and 5, respectively. Kinetic parameters including specific substrate utilization rate, half saturation constant, yield, etc of *Nitrosomonas* and *Nitrobacter* were summarized at different temperatures (Rittmann and Snoeyink 1984).



**Figure 5.** Phylogenetic tree of NOB based on a multiple alignment of 40 NOB 16S rDNA sequences. Abbreviations are Nb for *Nitrobacter* and Nsr for *Nitrospira*. *Rh. capsulatus* is in the *Alphaproteobacteria* class, *R. eutropha* is in the *Betaproteobacteria* class, and *E. coli* is in the *Gammaproteobacteria* class. Scale bar represents 10% sequence difference (Regan 2001)

#### 3.5. Removal of nitrate (denitrification) and perchlorate

With the application of nitrate containing fertilizers and consumption of animal products, more nitrate is discharged into rivers and lakes, which may cause eutrophication and elevated levels of nitrate in ground water and surface water. Although nitrate was not identified as a carcinogen to laboratory animals, methaemoglobinaemia forms as a consequence of the reaction of nitrite (reduced from nitrate in human bodies) with haemoglobin in the human red blood cells to form methaemoglobin, which binds oxygen tightly and does not release it, therefore blocks oxygen transport (WHO 2008). The maximal contamination level in drinking water was 10 mg/L nitrate nitrogen in US, Japan, and Korea. The European Union countries set the standard for nitrate nitrogen at 11.3 mg/L. World Health Organization recommends 11.3 mg/L nitrate nitrogen to protect against methaemoglobinaemia in bottle-fed infants. Traditionally, nitrate removal was achieved by biological denitrification, ion-exchange, adsorption, chemical reduction, and membrane separation such as reverse osmosis. Ion exchange and membrane processes were often applied for high purity water treatment, which will generate concentrated nitrate reject (usually need additional treatment) from resin or membranes. Biological treatment processes were widely used for wastewater and drinking water treatment.

Denitrification filters are a unique type of biologically active filter where an external carbon source is usually added to the filter to provide a food source to anoxic biology and facilitate the reduction of nitrates in the filter. As a result, a dedicated anoxic biology is likely developed in the filter.

It is generally recognized that denitrification is carried out in the following steps with the aid of various enzymes produced during the process in the form of intracellular and extracellular polymeric substances, i.e., nitrate reductase (Nar), nitrite reductase (Nir), nitric oxide reductase (Nor), and nitrous oxide reductase (Nos) (Rittmann and McCarthy 2001).

$$NO_3 - N \xrightarrow{Nar} NO_2 - N \xrightarrow{Nir} NO \xrightarrow{Nor} N_2O \xrightarrow{Nos} N_2$$

Denitrifiers are a group of heterotrophic bacteria and are phylogenetically diverse. They belong to over 50 genera and fall into all major physiological groups (Zumft 1992; Zumft 1997). Furthermore, microorganisms fed with different carbon sources showed distinct features. A report demonstrated that the metabolic profiles obtained from potential denitrification rates with 10 electron donors were altered with their preferences for certain compounds after supplementing methanol or ethanol, and that methanol had the greater impact (Hallin et al. 2006).

Denitrifying bacteria fed with methanol were recognized as methylotrophs. Fluorescence in situ hybridization (FISH) combined with microautoradiography (MAR) revealed that  $\alpha$ -*Proteobacteria* metabolized <sup>14</sup>C methanol in the presence of nitrate, suggesting their involvement in denitrification in a methanol-fed fluidized marine denitrification reactor (Labbe et al. 2007). Using a molecular tool, *Paracoccus* sp. and *Hyphomicrobium* spp. were identified as denitrifiers in a denitrification sand filter fed with methanol (Neef et al. 1996). Research showed that methanol denitrifiers and acetate denitrifiers were distinctively different. When acetate was used as the carbon source, 16S rRNA gene sequences obtained from <sup>13</sup>C-labeled DNA were closely related to the 16S rRNA genes of *Comamonadaceae* and *Rhodobacteraceae* of the  $\beta$ -*Proteobacteria*, and *Rhodobacteraceae* of the  $\alpha$ -*Proteobacteria*. When methanol was used as the carbon source, 16S rRNA gene sequences retrieved from <sup>13</sup>C-DNA were affiliated with *Methylophilaceae* and *Hyphomicrobiaceae* (Osaka et al. 2006).

A study showed that methanol-utilizing organisms can not use acetate or sugar (at least not immediately). Adding alternative carbon sources, i.e., acetate or sugar, will not result in an immediate improvement in denitrification (Dold et al. 2008). However, the substrate uptake rate ( $\mu$ max) and specific denitrification rate (SDNR), measured by feeding ethanol to methanol-utilizers, indicated that ethanol was also used essentially as easily and at a similar rate to methanol by the methanol-utilizers (Dold et al. 2008).

The stoichiometric and kinetic information for different carbon sources commonly used in a denitrification filter were studied previously and selected parameters are summarized elsewhere (Omnis-Hayden and Gu 2008). Table 7 summarized findings and operating parameters in previous studies. The important design parameters are EBCT, C/N ratio (the ratio of external carbon to nitrate nitrogen), pH and temperature.

Study Scales	Water	Parameters	Effluent Qualities,	References
	Qualities		Efficiencies, and	
			Findings	
Pilot up-flow	NO <sub>3</sub> -N 27 mg/L	EBCT 2.57	Close to 100% NO <sub>3</sub> -	(Holló and
fluidized sand filter		minutes	N removal	Czakó 1987)
(1.2 m deep 0.6-0.8		C/N 1.3		
mm sand)		(propionic acid)		
Pilot Rotating	NO3-N 40-250	NO3-N loading:	99% (for 76	(Mohseni-
Biological	mg/L	76 mg/m²∙h	mg/m²∙h) and 87%	Bandpi et al.
Contactors (RBC)	pH 7 and 20±2	490 mg/m²•h	(490 mg/m²∙h)	1999)
(75 m <sup>2</sup> )	°C	Acetic acid as a	The optimum C/N	
		carbon source	ratio 4.3	
Bench-scale	NO3-N 100-200	C/N ratio 2-4	99% removal with	(Fuchs et al.
membrane reactors.	mg/L	(ethanol)	denitrification rates	1997)
	20±1 ⁰C		up to 1.23 g NO <sub>3</sub> -	
			$N/m^2 \bullet d$	
Bench-scale up-flow	NO <sub>3</sub> -N 20 mg/L	EBCT 48	85% NO <sub>3</sub> -N removal	(Ueda et al.
fixed-bed reactor	25±1 ⁰C	minutes	with an optimum	2006)
		Molasses	C/N ratio 2	
Bench-scale	NO3-N 110		99% NO <sub>3</sub> -N removal	(Liu et al.
experiments.	mg/L		with NO <sub>2</sub> -N residual	2003)
Calcium tartrate (4%			(2-4 mg/L) higher	
w/w) co-			than expected	
immobilized in				
alginate beads with				
microorganisms				
Bench-scale carbon	NO3-N 200	EBCT 78	90% NO <sub>3</sub> -N removal	(Pekdemir et
packed fixed-	mg/L	minutes		al. 1998)
biofilm bed reactor,		C/N ratio 2-4		
inoculated with		(ethanol)		
Paracoccus denitrificans				
NRRL B-3784.				
Bench scale packed	NO3-N 50 mg/L	EBCT 30	NO3-N 0.9 mg/L;	(Dahab and
Pall Rings (16 mm	pH 7.5-7.8	minutes	NO2-N 0.7 mg/L;	Kalagiri 1996)
diameter and		COD/N ratio 4	COD 34 mg/L	
length) bed		(ethanol)		
Bench scale packed	NO3-N 50 mg/L	EBCT 30	NO3-N 2.4 mg/L;	(Woodbury
Pall Rings (16 mm	pH 7 and 20 °C	minutes	NO2-N 0.8 mg/L;	and Dahab
diameter and	_	COD/N ratio 4	COD 18 mg/L	2001)
length) bed		(ethanol)		
Full scale packed	NO <sub>3</sub> -N 20 mg/L	EBCT 66	NO3-N 5.0 mg/L;	(Silverstein
polypropylene	pH 7.2 and 13-	minutes	NO2-N 1.7 mg/L;	and Carlson
beads (3.8 mm and 5	18 ºC	COD/N ratio 5.3	COD 20 mg/L	1999)
mm diameter) bed		(corn syrup)	Č	

Study Scales	Water	Parameters	Effluent Qualities,	References
	Qualities		Efficiencies, and	
			Findings	
Pilot ceramic media	NO3-N 68 mg/L	EBCT 72	NO3-N <4 mg/L;	(Moreno et al.
bed (1.5 m	pH 7-7.5 and	minutes	NO2-N<3 mg/L;	2005)
high and 0.3 m	15-20 ºC	COD/N ratio 4.3	COD 10 mg/L	
diameter)		(ethanol)		
Bench scale	NO3-N 45 mg/L	EBCT 306	NO3-N 5 mg/L; NO2-	(Vrtovsek and
PVC/GAC beads	and 20 °C	minutes	N<0.5 mg/L; COD 60	Ros 2006)
bed (88 cm		COD/N ratio 5.5	mg/L	
high and 12 cm		(acetate)		
diameter)				
Bench scale moving	NO3-N 60 mg/L	EBCT 54	NO3-N 4.7 mg/L;	(Welander
bed (Kaldnes K1)	pH >7 and 20	minutes	NO2-N<0.25 mg/L;	and
	⁰C	COD/N ratio	COD 400 mg/L	Mattiasson
		13.1		2003)
		(acetate)		
Pilot 900 L moving	NO3-N 800	EBCT 17 hours	NO3-N ~0 mg/L;	(Welander et
bed reactor (carrier,	mg/L	COD/N ratio 4	NO2-N ~0 mg/L	al. 1998)
Natrix 6/6C, ANOX	pH 7.8 and 17	(acetate)		
AB, Lund)	<sup>o</sup> C			
Pilot moving plastic	NO3-N 13 mg/L	EBCT 26	NO3-N 2.0 mg/L;	(Rusten et al.
media bed	NO2-N 0.5	minutes	NO2-N 0.9 mg/L;	1995)
	mg/L	COD/N ratio 4	COD 50 mg/L	
	7-10 ºC	(acetate)		
Membrane	NO3-N 200	EBCT 26	NO3-N 5.7 mg/L;	(Ergas and
bioreactor with	mg/L	minutes	NO2-N 0.02 mg/L;	Rheinheimer
hollow-fibers (1.1	pH 7.2	COD/N ratio 3	COD 70 mg/L	2004)
mm inner diameter,		(methanol)		
1.4 mm external				
diameter, 0.38m				
length)				
Pilot-scale fixed-bed	ClO4-77 µg/L	EBCT 15	Reduced to <4 µg/L	(Min et al.
bioreactors packed		minutes		2004)
with sand or		Acetic acid as a		
plastics.		carbon source		
Six-month pilot at	10.00 NO	EBCT 15	Reduced to less than	(Brown et al.
the Castaic Lake	10-20 mg NO3-	minutes	detection limit	2005)
Water Agency,	IN/L	Acetic acid as a		
Santa Clarita, CA,	17-20 μg	carbon source		
using fixed-bed	ClO <sub>4</sub> -/L			
bioreactors				

Study Scales	Water	Parameters	Effluent Qualities,	References
	Qualities		Efficiencies, and	
			Findings	
Bench-scale	ClO4-50 µg/L	EBCT 25	Reduced to less than	(Brown et al.
Granular Activated		minutes	detection limit	2002)
Carbon (GAC)		Acetic acid as a		
bioreactor		carbon source		
Bench-scale	1,000 mg NO3-	EBCT 48 hours	80% nitrate removal	(Chung et al.
hydrogen	N/L and/or 500	72 cm <sup>2</sup>	and 60% ClO <sub>4-</sub>	2007)
permeable	mg ClO <sub>4</sub> -/L	membrane	removal (no nitrate);	
membrane fixed		surface	the presence of	
film reactor			nitrate reduced	
			ClO <sub>4</sub> - removal.	
Bench-scale	125 mg NO	EBCT 55	99.5% reduction of	(Ziv-El and
hydrogen	12.5 mg 1003-	minutes	0.21 mg NO <sub>3</sub> -	Rittmann
permeable	IN/L	83.6 cm <sup>2</sup>	N/cm <sup>2</sup> •d and 3.4 µg	2009)
membrane fixed	9.4 μg ClO4-/L	membrane	ClO₄/cm²•d	
film reactor		surface		
Pilot up-flow	NO3-N 325	EBCT 15 h	Completely removed	(Chung et al.
packed bed reactors	mg/L	pH of 7.0	perchlorate and	2010)
(plastic media)	ClO <sub>4</sub> - 6.37		nitrate with up to	
	mg/L		10% salinity	
Pilot anthracite filter	NO N2 ma/I	EBCT 47	Reduced to <2 µg/L	(Dugan et al.
(0.31 m deep and 1.0	$1003-10 \ge 1007$ L	minutes	with temperature as	2009)
mm ES)	ClO4-50 µg/L		low as 10 <sup>°</sup> C	

**Table 7.** Design parameters and findings for the removal of nitrate and perchlorate in previous studies

Perchlorate occurs in water due to natural presence or manufacturing for ammonia perchlorate (Srinivasan and Sorial 2009). Being a strong oxidant, perchlorate was used as solids propellants for rockets and missiles or used for fireworks. The US EPA is not currently regulating perchlorate in drinking water but already placed it in the contaminant candidate list.

Table 7 also summarized findings and operating parameters in previous studies for pechlorate removal. Usually perchlorate is removed simultaneously with nitrate. Because the standard oxidation potential of the perchlorate/chloride pair (1.28 V) is much higher than nitrate/N<sub>2</sub> pair (0.75 V), perchlorate is reduced preferentially, and can be reduced down to less than 4  $\mu$ g/L with an EBCT at least 15 minutes. High reduction rates of nitrate and perchlorate occurred in a synthetic high-strength salt medium 20 g/L (~2%) NaCl, while 40 g/L NaCl slowed reduction by 40% or more (Chung et al. 2010).

Similar to nitrate removal, biological processes are still cost effective for perchlorate removal. In an anoxic environment, perchlorate is reduced to chloride at the expense of an external carbon source.

# 4. Conclusions and perspectives

While BAFs are playing an important role in contaminant removal from water sources, understanding the process design parameters such as EBCT, media selection, backwash velocity, pH, temperature, oxygen demand, pre-oxidation requirement, inhibiting metal elements, etc, is important in that it will provide insights on treatment process control, pathogenic impacts, disinfection by-product control, and the potential to improve treatment efficiencies.

An EBCT of 10 minutes is generally recommended for the removal of TOC, MIB and geosmin, iron and manganese, arsenic, and ammonia. At least 15 minutes are generally required for the removal of nitrate and perchlorate. Backwash was found not influencing the process performance. A GAC/sand filter produced better performance than an anthracite/sand filter for the removal of NOM and taste and odor compounds, and the GAC/Sand filter out performed the anthracite/sand filter by 11% for AOC removal and showed better resistance to temperature at 1-3 °C. Unlike the situation with NOM, placing ozonation in front of GAC filters was not benefitting the removal of MIB and geosmin. Simple aeration is sufficient for providing oxygen for the removal of ammonia, and iron and manganese.

Effective microbial adhesion and immobilization is essential for biofilm activities, and still drives further research on physicochemical (for example roughing, grafting, coating, etc) and biological (inoculated with selected species) approach in BAFs. To improve the process efficiency, dedicated microbial species targeting specific contaminants are usually desired. However, it is challenging and presents significant scientific and engineering opportunities to select microbial communities in biofilms specifically adapted to targeted contaminants. Besides currently employed media, alternative cost effective media are always interested, especially the ones from waste materials and engineered with specific surface properties.

# Author details

Ivan X. Zhu and Brian J. Bates *Xylem Water Solutions Zelienople LLC, Zelienople, PA, USA* 

# 5. References

- Al-Ghouti MA, Khraisheh MAM, Allen SJ, Ahmad MN. 2003. The removal of dyes from textile wastewater: a study of the physical characteristics and adsorption mechanisms of diatomaceous earth. J. Environ. Manage. 69:229-238.
- Amirtharajah A. 1993. Optimum backwashing of filters with air scour: a review. Wat. Sci. Tech. 27(10):195-211.
- Andersson A, Laurent P, Kihn A, Prévost M, Servais P. 2001. Impact of temperature on nitrification in biological activated carbon (BAC) filters used for drinking water treatment. Water Res. 35(12): 2923–2934.

- AWWA. 2006. Manual of Water Supply Practices—M56. Kozyra MK, editor. Denver: Glacier Publishing Services, Inc.
- Babbitt HE, Doland JJ. 1939. Water Supply Engineering. New York: McGraw Hill.
- Barrett JM, Bryck J, Collins MR, Janonis BA, Logsdon GS. 1991. Manual of Design of Slow Sand Filtration. Hendricks D, editor. Denver: AWWA RF and AWWA.
- Bourbigot MM, Dodin A, Lheritier R. Limiting bacterial aftergrowth in distribution systems by removing biodegradable organics; 1982; Miami.
- Bouwer EJ, Crowe PB. 1988. Biological processes in drinking water treatment. J AWWA September:82-93.
- Brown JC, Anderson RD, Min JH, Boulos L, Prasifka D, Juby GJG. 2005. Fixed-bed biological treatment of perchlorate-contaminated drinking water. J. AWWA 97(9):70-81.
- Brown JC, Snoeyink VL, Kirisits MJ. 2002. Abiotic and biotic perchlorate removal in an activated carbon filter. J. AWWA 94(2):70-79.
- Brunet B, Dictor MC, Carrido F, Crouzet C, Morin D, Dekeyser K, Clarens M, Baranger P. 2002. An arsenic(III) oxidizing bacterial population: selection, characterization, and performance in reactors. J. Appl. Microbiol. 93:656–667.
- Burger MS, Mercer SS, Shupe GD, Gagnon GA. 2008. Manganese removal during benchscale biofiltration. Water Res. 42:4733-4742.
- Camper AK, Lechevallier MW, Broadaway SC, Mcfeters GA. 1985. Growth and persistence of pathogens on granular activated carbon filters. Appl. Environ. Microbiol. 50(6):1378-1382.
- Cantor KP, Hoover R, Hartge P, Mason TJ, Silverman DT, Altman R, Austin DF, Child MA, Key CR, Marrett LD and others. 1987. Bladder cancer, drinking water source, and tap water consumption: a case-control study. J. Natl Cancer Institute 79(6):1269-1279.
- Cantor KP, Lynch CF, Hildesheim ME, Dosemeci M, Lubin J, Alavanja M, Craun G. 1999. Drinking water source and chlorination byproducts in Iowa. III. Risk of brain cancer. Am J Epidemiol. 150(6):552-560.
- Carlson KH, Amy GL. 2001. Ozone and biofiltration optimization for multiple objectives. J. AWWA 93(1):88-98.
- Carraro E, Bugliosi EH, Meucci L, Baiocchi C, Gilli G. 2000. Biological drinking water treatment processes, with special reference to mutagenicity. Water Res. 34(11):3042–3054.
- Chaiket T, Singer PC, Miles A, Morgan M, Pallotta C. 2002. Effectiveness of coagulation, ozonation, and biofiltration in controlling DBPs. J. AWWA 94(12):81-95.
- Characklis WG. 1988. Bacterial Regrowth in Distribution Systems. Denver: AWWA RF and AWWA.
- Chung J, Nerenberg R, Rittmann BE. 2007. Evaluation for biological reduction of nitrate and perchlorate in brine water using the hydrogen-based membrane biofilm reactor. J. Environ. Eng. 133(2):157-164.
- Chung J, Shin S, Oh J. 2010. Biological reduction of nitrate and perchlorate in brine water using up-flow packed bed reactors. J. Environ. Sci. Health Part A 45:1109-1118.
- Collins MR, Eighmy TR, Fenstermacher JM, Spanos SK. 1992. Removing natural organic matter by conventional slow sand filtration. J. AWWA 84(5):80-90.

- Dahab MF, Kalagiri J. 1996. Nitrateremoval from water using cyclicallyoperated fixedfilm bio-denitrification reactors. Wat. Sci. Technol. 34(1-2):331-338.
- Davidson MI, Bryant R, Williams DJA. 1996. Characterization of anthracite. Geological Society, London, Special Publications 109:213-225.
- Dold P, Takács I, Mokhayeri Y, Nichols A, Hinojosa J, Riffat R, Bott C, Bailey W, Murthy S. 2008. Denitrification with carbon addition—kinetic considerations Water Environ. Res. 80(5):417-427.
- Doyle TJ, Sheng W, Cerhan JR, Hong CP, Sellers TA, Kushi LH, Folsom AR. 1997. The association of drinking water source and chlorination by-products with cancer incidence among postmenopausal women in Iowa: a prospective cohort study. Am. J. Public Health 87(7):1168-1176.
- Dugan NR, Williams DJ, Meyer M, Schneider RS, Speth TF, Metz DH. 2009. The impact of temperature on the performance of anaerobic biological treatment of perchlorate in drinking water. Water Res. 43:1867-1878.
- Dussert BW, Van Stone GR. 1994. The biological activated carbon process for water purification. Water Eng. Manage. 141(12):22-24.
- Edwards M. 1994. Chemistry of arsenic removal duirng coagulation and Fe-Mn oxidation. J. AWWA 86(9):64-78.
- Elhadi SLN, Huck PM, Slawson RM. 2004. Removal of geosmin and 2-methylisoborneol by biological filtration. Water. Sci. Technol. 49(9):273-280.
- Elhadi SLN, Huck PM, Slawson RM. 2006. Factors afecting the removal of geosmin and MIB in drinking water biofilters. J. AWWA 98(8):108-119.
- Elliot P, Ragusa S, Catcheside D. 1998. Growth of sulphate reducing bacteria under acid conditions in an up-flow anaerobic bioreactor as a treatment system for acid mine drainage. Water Res. 32:3724–3730.
- Emelko MB, Huck PM, Coffey BM, Smith EF. 2006. Effects of media, backwash, and temperature on full scale biological filtration. J. AWWA 98(12):61-73.
- Ergas SJ, Rheinheimer DE. 2004. Drinking water denitrification using amembranebioreactor. Water Res. 38(14-15):3225-3232.
- EU Council. 1980. Council Directive 98/83/EC of 3 November 1998 on the Quality of Water Intended for Human Consumption. EC Drinking Water Directive.
- Evans P, Opitz E, Daniel P, Shultz C, Skerly A, Shivakumar S. Preliminary results of a survey on the use of biological processes for drinking water treatment; 2008; Cincinnati, Ohio. AWWA.
- Forster JRM. 1974. Studies on nitroification in marine biological filters. Aquaculture 4:387-397.
- Fuchs W, Schatzmayr G, Braun R. 1997. Nitrate removal from drinking water using a membrane-fixed biofilm reactor. Appl Microbiol Biotechnol. 48(2):267-274.
- Gayer KH, Woontner L. 1956. The solubility of ferrous hydroxide and ferric hydroxide in acidic and basic media at 25 °C. J. Phys. Chem. 60:1569-1571.
- Gergova K, Eser S, Schobert HH. 1993. Preparation and characterization of activated carbons from anthracite. Energy & Feuls 7:661-668.

- Goel S, Hozalski RM, Bouwer EJ. 1995. Biodegradation of NOM: effect of NOM source and ozone dose. J. AWWA 87(1):90-105.
- Gottinger AM. 2010. Chemical-free arsenic removal from potable water with a zvi-amended biofilter. Regina: University of Regina.
- Hallin S, Throbäck IN, Dicksved J, Pell M. 2006. Metabolic profiles and genetic diversity of denitrifying communities in activated sludge after addition of methanol or ethanol. Appl. Environ. Microbiol. 72(8):5445-5452.
- Hering JG, Chen PY, Wilkie JA, Elimelech M. 1997. Arsenic removal from drinking water during coagulation. J. Environ. Eng. 123:800-807.
- Ho L, Hoefel D, Bock F, Saint CP, Newcombe G. 2007. Biodegradation rates of 2methylisoborneol (MIB) and geosmin through sand filters and in bioreactors. Chemosphere 66:2210-2218.
- Holló J, Czakó L. 1987. Nitrate removal from drinking water in a fluidized-bed biological denitrification bioreactor. Acta Biotechnologica 7(5):417-423.
- Hozalski RM, Bouwer EJ, Goel S. 1999. Removal of natural organic matter (NOM) from drinking water supplies by ozone biofiltration. Wat. Sci. Tech. 40(9):157-163.
- Hozalski RM, Goel S, Bouwer EJ. 1995. TOC removal in biological filters. J. AWWA 87(12):40-54.
- Jerez J, Flury M, Shang J, Deng Y. 2006. Coating of silica sand with aluminosilicate clay. J. Colloid Interface Sci. 294:155-164.
- Jong T, Pany DL. 2003. Removal of sulfate and heavy metals by sulfate reducing bacteria in short term bench scale up-flow anaerobic packed bed reactor runs. Water Res. 37:3379–3389.
- Juhna T, Rubulis J. 2004. Problem of DOC removal during biological treatment of surface water with a high amount of humic substances. Water Sci. & Technol.: Water Supply 4(4):183-197.
- Kasuga I, Shimazaki D, Kunikane S. 2007. Influence of backwashing on the microbial community in a biofilm developed on biological activated carbon used in a drinking water treatment plant. Water Sci. & Technol. 55(8-9):173-180.
- Katsoyiannis I, Zouboulis A, Althoff H, Bartel H. 2002. As(III) removal from groundwaters using fixed-bed upflow bioreactors. Chemosphere 47:325-332.
- Katsoyiannis IA, Zouboulis AI. 2004. Application of biological processes for the removal of arsenic from groundwaters. Water Res. 38:17-26.
- Kitis M, Kaplan SS, Karakaya E, Yigit NO, Civelekoglu G. 2007. Adsorption of natural organic matter from waters by iron coatedpumice. Chemosphere 66(1):130-138.
- Labbe N, Laurin V, Juteau P, Parent S, Villemur R. 2007. Microbiological community structure of the biofilm of a methanol-fed, marine denitrification system, and identification of the methanol-utilizing microorganisms. Microb. Ecol. 53(4):621-630.
- Lauderdale CV, Brown JC, chadik PA, Kirisits MJ. 2011. Engineered Biofiltration for Enhanced Hydraulic and Water Treatment Performance. Denver: Water Research Foundation.

- Laurent P, Prevost M, Cigana J, Niquette P, Servais P. 1999. Biodegradable organic matter removal in biological filters: evaluation of the chabrol model. Water Res. 33(6):1387-1398.
- Liu SX, Hermanowicz SW, Peng M. 2003. Nitrate removal from drinking water through the use of encapsulated microorganisms in alginate beads. Environ. Technol. 24(9):1129-1134.
- Liu XT, Li D, Zeng HP, Zhang J. 2010. Arsenic(III) removal by biofilter for iron and manganese removal. Journal of Harbin Institute of Technology 42(6):873-875.
- Logsdon GS, Hess AF, Chipps MJ, Rachwal AJ. 2002. Filter Maintenance and Operations Guidance Manual. Denver: AWWA RF and AWWA.
- Lytle DA, Chen AS, Sorg TJ, Phillips S, French K. 2007a. Microbial As(III) oxidation in water treatment plant filters. J. AWWA 99(12):72-86.
- Lytle DA, Sorg TJ, Lili W, Muhlen C, Rahrig M, French K. 2007b. Biological nitrification in a full-scale and pilot-scale iron removal drinking water treatment plant. J. Water Supply : Res. Technol. AQUA 56(2):125-136.
- McDowall B, Ho L, Saint C, Newcombe G. 2007. Removal of geosmin and 2methylisoborneol through biologically active sand filters. Int J. Environ. Waste Manage. 1(4):311-320.
- McGovern B, Nagy R. Biological removal of iron, ammonia, and manganese simultaneously utilizing pressurized downflow filtration; 2010 November 14–18; Savannah, GA. AWWA.
- Melin ES, Odegaard H. 1999. Biofiltration of ozonated humic water in expanded clay aggregate filters. Wat. Sci. Tech. 40(9):165-172.
- Min B, Evans PJ, Chu AK, Logan BE. 2004. Perchlorate removal in sand and plastic media bioreactors. Water Res. 38(1):47-60.
- Mohseni-Bandpi A, Elliott DJ, Momeny-Mazdeh A. 1999. Denitrification of groundwater using aceticacid as a carbon source. Water Sci. Technol. 40(2):53-59.
- Mondal P, Majumder CB, B. Mohanty B. 2008. Treatment of arsenic contaminated water in a laboratory scale up-flow bio-column reactor. J. Hazard. Mat. 153:136-145.
- Moreno B, Gómez MA, González-López J, Hontoria E. 2005. Inoculation of a submerged filter for biological denitrification of nitrate polluted groundwater: a comparative study. J. Hazard Mater. 117(2-3):141-174.
- Najm I, Kennedy M, Naylor W. 2005. Lignite versus bituminous GAC for biofiltration a case study. J. AWWA 97(1):94-101.
- Ndiongue S, Anderson WB, Tadwalkar A, Rudnickas J, Lin M, Huck PM. 2006. Using pilotscale investigations to estimate the remaining geosmin and MIB removal capacity of full-scale GAC-capped drinking water filters. Water Qual. Res. J. Canada 41(3):296-306.
- Neef A, Zaglauer A, Meier H, Amann R, Lemmer H, Schleifer KH. 1996. Population analysis in a denitrifying sand filter: conventional and In situ identification of *Paracoccus* spp. in methanol-fed biofilms. Appl. Environ. Microbiol. 62(12):4329–4339.
- Nerenberg R, Rittmann BE, Soucie Wj. 2000. Ozone/biofiltration for removing MIB and Geosmin. J. AWWA 92(12):85-95.

- Occelli ML, Olivier JP, Perdigon-Melon JA, Auroux A. 2002. Surface area, pore volume distribution, and acidity in mesoporous expanded clay catalysts from hybrid density functional theory (DFT) and adsorption microcalorimetry methods. Langmuir 18(9816-9823).
- Oliveira LCA, Rios RVRA, Fabris JD, Garg V, Sapag K, Lago RM. 2002. Activated carbon/iron oxide magnetic composites for the adsorption of contaminants in water. Carbon 40:2177-2183.
- Omnis-Hayden A, Gu AZ. Comparison of organic sources for denitrification: biodegradability, denitrification rates, kinetic constants and practical implication for their application in WWTPs; 2008 October 20-22; Chicago. WEF. p 253-273.
- Osaka T, Yoshie S, Tsuneda S, Hirata A, Iwami N, Inamori Y. 2006. Identification of acetateor methanol-assimilating bacteria under nitrate-reducing conditions by stable-isotope probing. Microb. Ecol. 52(2):253-266.
- Pacini VA, Ingallinella AM, Sanguinetti G. 2005. Removal of iron and manganese using biological roughing up flow filtration technology. Water Res. 39:4463-4475.
- Partinoudi V, Collions MR. 2007. Assessing RBF reduction/removal mechanisms for microbial and organic DBP precursors. J. AWWA 97(12):61-71.
- Pekdemir T, Kacmazoglu EK, Keskinler B, Algur OF. 1998. Drinking water denitrification in a fixed bed packed biofilm reactor. Turk. J. Eng. Environ. Sci. 22(1):39-45.
- Perrotti AE, Martins SAM, Mazzola PG. 1974. Factors involved with biological regeneration of activated carbon. AIChE Sym. Series 144:317–325
- Persson F, Heinicke G, Hedberg T, Hermansson M, Uhl W. 2007. Removal of geosmin and mib by biofiltration an investigation discriminating between adsorption and biodegradation. Environ. Technol. 28:95-104.
- Piet GJ, Zoeteman BCJ. 1980. Organic water quality changes during sand bank and dune filtration of surface waters in Netherlands. J. AWWA 72(7):400-404.
- Pokhrel D, Viraraghavan T. 2009. Biological filtration for removal of arsenic from drinking water. J. Environ. Manage. 90:1956-1961.
- Pokhrel D, Viraraghavan T, Braul L. 2005. Evaluation of treatment systems for the removal of arsenic from groundwater. Pract. Period. Hazard. Toxic Radioact. Waste Manage. 9:152-157.
- Ratnayaka DD, Brandt MJ, Johnson KM. 2009. Water Supply. Oxford, UK: Elsevier Ltd.
- Regan JM. 2001. Microbial Ecology of Nitrification in Chloraminated Drinking Water Distribution Systems. Madison: University of Wisconsin.
- Rice RG, Robson RG. 1982. Biological Activated Carbon. Ann Arbor, Michigan: Ann Arbor Science.
- Rittmann BE, McCarthy PL. 2001. Environmental Biotechnology: Principles and Applications. New York: McGraw-Hill.
- Rittmann BE, Snoeyink VL. 1984. Achieving biologically stable drinking water. J. AWWA 10:106-114.
- Rittmann BE, Stilwell D, Garside JC, Amy GL, Spangenberg C, Kalinsky A, Akiyoshi E. 2002. Treatment of a colored groundwater by ozone-biofiltration: pilot studies and modeling interpretation. Water Res. 36:3387-3397.

- Rodman CA, Shunney EL, Perrotti AE. 1978. Biological Regenration of Activated Carbon. Cheremisinoff PN, Ellerbursch F, editors. Ann Arbor, Michigan: Ann Arbor Science.
- Rogalla F, Ravarini P, De Larminat G, Couttelle J. 1990. Large-scale biological nitrate and ammonia removal. J. IWEM 4(4):319-328.
- Rollingger Y, Dott W. 1987. Survival of selected bacterial species in sterilized activated carbon filters and biological activated carbon filters. Appl. Environ. Microbiol. 53(4):777-781.
- Rusten B, Hem LJ, Ødegaard H. 1995. Nitrogen removal from dilute wastewater in cold climate using moving-bed biofilm reactors. Water Environ. Res. 67(1):65-74.
- Scholz M, Martin J. 1997. Ecological equilibrium on biological activated carbon. Water Res. 31(12):2959-2968.
- Shukairy HM, Miltner RJ, Summers RS. 1992. Control of disinfection by-products and biodegradable organic matter through biological treatment. Revue des sciences de l'eau 5:1-15.
- Siddiqui MS, Amy GL, Murphy BD. 1997. Ozone enhanced removal of natural organic matter from drinking water sources. Water Res. 31(12):3098-3106.
- Silverstein JS, Carlson GL. 1999. Biological Denitrification of Drinking Water for Rural Communities. Final Project Report. NRECA (National Rural Electric Cooperative Association) and EPRI (Electric Power Research Institute).
- Sontheimer H. 1980. Experience with riverbank filtration along the Rhine River. J. AWWA 72(7):386-390.
- Srinivasan R, Sorial GA. 2009. Treatment of perchlorate in drinking water: a critical review. Separation and Purification Technol. 69:7-21.
- Štembal T, Markic M, Ribicic N, Briski F, Sipos L. 2005. Removal of ammonia, iron and manganese from groundwaters of northern Croatia—pilot plant studies. Process Biochem. 40:327-335.
- Swain HA, Lee C, Rozelle RB. 1975. Determination of the solubility of manganese hydroxide and manganese dioxide at 25 °C by atomic absorption spectrometry. Anal. Chem. 47(7):1135-1137.
- Tang Z, Maroto-Valer MM, Zhang Y. 2004. CO2 capture using anthracite based sorbents. Prepr. Pap.-Am. Chem. Soc., Div. Fuel Chem. 49(1):298-299.
- Tekerlekopoulou AG, Vasiliadou IA, Vayenas DV. 2008. Biological manganese removal from potable water using trickling filters. Biochem. Eng. J. 38:292-301.
- Ueda T, Shinogi Y, Yamaoka M. 2006. Biological nitrate removal using sugar-industry wastes. Paddy Water Environ. 4(3):139-144.
- Unger M, Collins MR. 2008. Assessing *Escherichia coli* removal in the *Schmutzdecke* of slow rate biofilters. J. AWWA 100(12):60-73.
- van der Hoek JP, Hofman JAMH, Graveland A. 1999. The use of biological activated carbon filtration for the removal of natural organic matter and organic micropollutants from water. Wat. Sci. Tech. 40(9):257-264.
- Vik EA, Storhaug R, Naes H, Utkilen HC. 1988. Pilot scale studies of Geosmin and 2-Methylisoborneol removal. Water Sci. & Technol. 20(8-9):229–236

- Vrtovsek J, Ros M. 2006. Denitrification of groundwater in the biofilm reactor with a specific biomass support material. Acta Chim. Slov. 53:396-400.
- Weiss J, Bouwer EJ, Ball WP, O'Melia CR, LeChevallier MW, Arora H, Speth TF. 2003. Riverbank filtration - fate of DBP precursors and selected microorganisms. J. AWWA 95(10):68-81.
- Welander U, Henrysson T, Welander T. 1998. Biologicalnitrogenremoval from municipal landfill leachate in apilotscalesuspendedcarrierbiofilmprocess. Water Res. 32(5):1564-1570.
- Welander U, Mattiasson B. 2003. Denitrification at low temperatures using a suspended carrier biofilm process. Water Res. 37(10):2394-8.
- WHO. 2008. Guidelines for Drinking-water Quality. Geneva, Switzerland: WHO Press.
- Woodbury BL, Dahab MF. 2001. Comparison of conventional and two-stage reversible flow, static-bed biodenitrification reactors. Water Res. 35(6):1563-1571.
- Yavich AA, Masten SJ. 2003. Use of ozonation and FBT to control THM precursors. J. AWWA 95(4):159-171.
- Zhang Y, Love N, Edwards M. 2009. Nitrification in drinking water systems. Crit. Rev. Environ. Sci. and Technol. 39:153-208.
- Zhu S, Chen S. 2002. The impact of temperature on nitrification rate in fixed film biofilters. Aquacultural Eng. 26(4):222-237.
- Ziv-El MC, Rittmann BE. 2009. Systematic evaluation of nitrate and perchlorate bioreduction kinetics in groundwater using a hydrogen-based membrane biofilm reactor. Water Res. 43:173-181.
- Zumft WG. 1992. The denitrifying prokaryotes. In: Balows A, Trüper HG, Dworking M, Harder W, Schleifer KH, editors. The Prokaryotes. 2 ed. New York, Berlin, Heidelberg: Springer-Verlag. p 554–582.
- Zumft WG. 1997. Cell biology and molecular basis of denitrification. Microbiol. Mol. Biol. Rev. 61(4):533-616.

