Grid Synchronization and Voltage Analysis Based on the Kalman Filter

Rafael Cardoso¹ and Hilton Abílio Gründling²

¹*Federal University of Technology – Paraná
Energy Processing and Analysis Research Group*

²*Federal University of Santa Maria
Power Electronics and Control Research Group
Brazil*

1. Introduction

This chapter deals with the problem of grid synchronization in the presence of several perturbations such as harmonics, voltage unbalance, measurement noise, transients and frequency deviation. The development of two synchronization structures is presented, one for single-phase systems and the other for three-phase systems. These schemes are based on the Kalman filter and all the aforementioned perturbations are incorporated, explicitly, in the problem formulation. A voltage analyser is also developed based on the three-phase synchronization structure.

Determining the phase angle of grid voltages is important for many power conditioning devices such as active power filters, reactive power compensators, uninterruptible power supplies, distributed power generation systems, among others, that must be appropriately synchronized with grid voltages. Due to the dynamic nature of the power system, the synchronization method chosen must be capable of rejecting many perturbations inherent to the system, such as harmonics, voltage sags and swells, imbalance, frequency deviations, measurement noise and phase angle jump (Svensson, 2001; Karimi-Ghartemani & Iravani, 2004; Blaabjerg et al., 2006).

A traditional approach to the extraction of the phase angle is the use of closed-loop techniques, such as Phase-Locked Loops (PLLs) (Hsieh & Hung, 1996). For three-phase applications, the phase angle is usually obtained by means of the well-known synchronous reference frame PLL. Implementation of these methods is straightforward but they suffer from the presence of harmonics and voltage imbalance as described in (Chung, 2000). Further analysis of the behaviour of the synchronous reference frame PLL under distorted and unbalanced utility conditions can be found in (Kaura & Blasko, 1997), where some tuning recommendations are also made to minimize the impact of the harmonics and voltage unbalance in phase angle tracking. In (Timbus et al., 2006), an improved PLL, based on a repetitive controller, is proposed. This PLL has a simple structure and is capable of rejecting the negative sequence.

Another closed-loop approach is the Enhanced Phase-Locked Loop (EPLL) (Karimi-Ghartemani & Iravani, 2004). This structure is based on use of the gradient method and

Source: Kalman Filter: Recent Advances and Applications, Book edited by: Victor M. Moreno and Alberto Pigazo,
ISBN 978-953-307-000-1, pp. 584, April 2009, I-Tech, Vienna, Austria

three gains are used to tune the algorithm. Like the PLL, the choice of its gains will influence its tracking capability. Since there is no rule to guide the choice of gains, tuning them by trial and error can be tedious. The concept of the EPLL is further elaborated in (Rodríguez et al., 2006) and a new Dual EPLL (DEPLL) is discussed. According to the authors, the DEPLL can lead to detection errors under certain grid conditions. The Dual Second Order Generalized Integrator-Frequency Locked Loop (DSOGI-FLL) was later proposed to overcome the drawbacks of the DEPLL.

Open-loop techniques have also been described in the literature. In (Song & Nam, 2000) an approach based on weighted least-squares that is capable of rejecting the effects of the negative-sequence and of accommodating frequency variations is proposed. However, it is sensitive to the presence of noise and harmonics in the voltages and presents long transients in detecting frequency variations. Another simple method is the PLL based on low-pass filters (LPF-PLL) (Svensson, 2001). This method is simple but has shortcomings. The filtering process introduces a phase shift that must be compensated by a rotation matrix. The phase shift is a function of the frequency and, since this method does not consider frequency variations, full compensation of the phase shift is not possible. Voltage imbalance is also not considered and there must be a trade-off between harmonic rejection and convergence speed, defined by the cut-off frequency of the low-pass filters. Because of oscillatory behaviour, its use is not recommended for systems subjected to phase jumps (Svensson, 2001). The Normalized Positive Synchronous Frame (NPSF) is another synchronization method that is also based on low-pass filters and considers voltage imbalance and frequency deviations (De Camargo & Pinheiro, 2006). In this method, the cut-off frequency of the low-pass filters tracks the grid frequency based on an adaptation algorithm. The main drawback is that the only tuning parameter is the convergence rate of the frequency identifier. Neither the convergence speed nor harmonic rejection can be modified since the cut-off frequencies of low-pass filters must be the same as the grid frequency.

A possible alternative to extract the phase angle of a signal is the use of the Kalman filter (Kalman, 1960). This filter is well known due to its ability to deal with linear systems corrupted by uncertainties in the states of the plant as well as measurement noise. The spectrum of this type of noise is usually distributed over a wide range of frequencies which can be modelled as white noise (Gelb et al., 1996). The elimination of this perturbation by traditional filtering methods is not straightforward because of the significant phase changes that the signal can suffer. Since the Kalman filter is an optimal algorithm that considers this type of perturbation in its formulation, it is a promising alternative for extracting the phase information from a noisy signal of interest.

Some authors have studied the relation between the Kalman filter and PLL (Gupta, 1975; Christiansen, 1994; Driessen 1994; Patapounian, 1999; Izadi & Leung, 2002). Synchronization methods based on the Kalman filter are mostly used in telecommunication systems and do not consider the presence of disturbances in the signal of interest, such as harmonics and voltage sags and swells that occur in the power system; nor are they appropriate for three-phase systems. Another approach is the use of the extended Kalman filter (Svensson, 2001). However, the extended Kalman filter uses linearizations around the estimates provided by the filter. Since the linearizations are applied using the last available estimate, the propagation equations are only valid if the estimate is not very distant from the actual state (Boutayeb et al., 1997). Moreover, an arbitrary choice of filter covariance matrices together with initial filter states not sufficiently close to the actual states may lead to a filter that fails to converge (Boutayeb et al., 1999).

This chapter describes single and three-phase synchronization methods based on the Kalman filter. They are termed the Kalman Filter-Phase Locked Loop (KF-PLL) and were first introduced in (Cardoso et al., 2006) with further developments presented in (Cardoso et al., 2008). As will be shown, the Kalman gain can be evaluated off-line, so that the filter can be implemented using fixed gains, simplifying its digital implementation. The proposed method is capable of generating synchronization signals even with input signals that contain harmonics and measurement noise. To achieve this, a mathematical model that considers the existence of harmonics in the signal, and also allows for the possible occurrence of transient voltages is used. As this model involves the grid frequency, the performance of the filter may be reduced if the grid frequency deviates from the value considered in the filter. Therefore, the fundamental grid frequency is also identified and is used to update the mathematical model used in the filter. The identification procedure is based on the internal model principle (Francis & Wonham, 1976) in a way similar to that presented in (Brown & Zhang, 2004). However, the present identification method uses a modified input signal and, in contrast to (Brown & Zhang, 2004), the algorithm is entirely derived in discrete form. The first discrete implementation of such an algorithm appeared in (Zhao & Brown, 2004) but their derivation is not clear. In this chapter, the discrete derivation is presented entirely for a better understanding of its discrete implementation. For the three-phase case, the possibility of voltage imbalance is also considered, and since the Kalman filter is an optimum algorithm, the results represent a good compromise between transient response and disturbance rejection. If the stochastic model of the process to be filtered is completely known, the obtained results are optimum according to several optimization criteria (Maybeck, 1979). Performance comparisons of the proposed synchronization structures with other methods presented in literature are available in (Cardoso et al., 2008). The use of the KF-PLL is also presented for purposes of voltage analysis, where several data about the grid voltages are extracted. For instance, harmonic content with their respective amplitudes, total harmonic distortion, positive, negative and zero sequence components, and further comments on synchronization with negative and zero sequences are also addressed.

This chapter is organized as follows: Section 2 presents the Kalman filter equations. Section 3 introduces the mathematical modeling of a signal with harmonics. The grid frequency identification is described in Section 4. The proposed synchronization methods are developed in Section 5. The use of the KF-PLL for voltage analysis is presented in Section 6. Digital implementation in a fixed point DSP TMS320F2812 is described in Section 7. Finally, the results of real time experiments are given in Section 8 and conclusions are presented in Section 9.

2. The Kalman filter

Consider a discrete linear dynamic stochastic system modeled by

$$\mathbf{x}_{k+1} = \Phi_k \mathbf{x}_k + \Gamma_k \gamma_k, \quad (1)$$

$$\mathbf{y}_k = \mathbf{F}_k \mathbf{x}_k + \mathbf{v}_k, \quad (2)$$

$$\dim \mathbf{x}_k = n \times 1, \dim \mathbf{y}_k = r \times 1, \dim \gamma_k = p \times 1, \quad (3)$$

where γ_k and $\mathbf{v}_k$ are independent Gaussian white noise sequences with means and covariances given by

$$E\{\gamma_i\} = 0, E\{\gamma_i \gamma_j^T\} = \mathbf{Q}_i \delta_{ij}, \quad (4)$$

$$E\{\mathbf{v}_i\} = 0, E\{\mathbf{v}_i \mathbf{v}_j^T\} = \mathbf{R}_i \delta_{ij}, \quad (5)$$

$$E\{\gamma_i \mathbf{v}_j^T\} = 0, E\{\gamma_i \mathbf{x}_j^T\} = 0, E\{\mathbf{v}_i \mathbf{x}_j^T\} = 0, \forall i, j, \quad (6)$$

where $E\{\cdot\}$ denotes the expectation mathematical operator and δ_{ij} denotes the Kronecker Delta function. The matrices Φ_k , Γ_k and $\mathbf{F}_k$ have appropriate dimensions.

Denoting by $\hat{\mathbf{x}}_{k+1|k}$ the estimate of $\mathbf{x}_{k+1}$ based on all the measurements up to k , the filtering equation as given in (Brown, 1992) is

$$\hat{\mathbf{x}}_{k+1|k} = \Phi_k \hat{\mathbf{x}}_{k|k-1} + \mathbf{K}_k (\mathbf{y}_k - \mathbf{F}_k \hat{\mathbf{x}}_{k|k-1}) \quad (7)$$

where

$$\mathbf{K}_k = \Phi_k \mathbf{P}_{k|k-1} \mathbf{F}_k^T (\mathbf{F}_k \mathbf{P}_{k|k-1} \mathbf{F}_k^T + \mathbf{R}_k)^{-1} \quad (8)$$

is the Kalman gain and

$$\mathbf{P}_{k+1|k} = \Phi_k \mathbf{P}_{k|k-1} \Phi_k^T - \mathbf{K}_k \mathbf{F}_k \mathbf{P}_{k|k-1} \Phi_k^T + \Gamma_k \mathbf{Q}_k \Gamma_k^T \quad (9)$$

is the covariance matrix of the estimation error of the vector $\mathbf{x}_{k+1}$ evaluated at time t_k :

$$\mathbf{P}_{k+1|k} \stackrel{\Delta}{=} E\left\{(\mathbf{x}_{k+1} - \hat{\mathbf{x}}_{k+1|k})(\mathbf{x}_{k+1} - \hat{\mathbf{x}}_{k+1|k})^T\right\}. \quad (10)$$

The initial conditions are given by $\hat{\mathbf{x}}_{0|-1}$ and $\mathbf{P}_{0|-1}$. Further details can be found in (Brown, 1992).

3. Describing a signal with harmonics

To use the Kalman filter presented in section 2 a mathematical model that describes the process to be filtered is needed. Thus, to obtain a mathematical model that adequately represents grid voltage dynamics, a signal that contains only the fundamental component is initially considered; harmonic components are introduced subsequently. Hence, consider a signal with amplitude A_k , angular frequency ω_k and phase θ_k

$$S_k = A_k \sin(\omega_k t_k + \theta_k). \quad (11)$$

Let

$$x_{1k} = A_k \sin(\omega_k t_k + \theta_k) \quad (12)$$

and

$$x_{2k} = A_k \cos(\omega_k t_k + \theta_k). \quad (13)$$

Initially, consider $A_{k+1} \approx A_k$, $\omega_{k+1} \approx \omega_k$ and $\theta_{k+1} \approx \theta_k$. At the time $t_{k+1} = t_k + T_s$ the signal S_{k+1} can be expressed as

$$\begin{aligned} S_{k+1} &= A_{k+1} \sin(\omega_k t_k + \omega_k T_s + \theta_{k+1}) = x_{1_{k+1}} \\ &= x_{1_k} \cos(\omega_k T_s) + x_{2_k} \sin(\omega_k T_s) \end{aligned} \quad (14)$$

where T_s is the sampling period.

Additionally,

$$\begin{aligned} x_{2_{k+1}} &= A_{k+1} \cos(\omega_k t_k + \omega_k T_s + \theta_{k+1}) \\ &= -x_{1_k} \sin(\omega_k T_s) + x_{2_k} \cos(\omega_k T_s). \end{aligned} \quad (15)$$

To model amplitude or phase variations in the signal, a perturbation vector $\begin{bmatrix} \gamma_1 & \gamma_2 \end{bmatrix}_k^T$ in the system states is considered. The state-space representation of the signal then becomes

$$\begin{bmatrix} x_1 \\ x_2 \end{bmatrix}_{k+1} = \begin{bmatrix} \cos(\omega_k T_s) & \sin(\omega_k T_s) \\ -\sin(\omega_k T_s) & \cos(\omega_k T_s) \end{bmatrix} \begin{bmatrix} x_1 \\ x_2 \end{bmatrix}_k + \begin{bmatrix} \gamma_1 \\ \gamma_2 \end{bmatrix}_k, \quad (16)$$

$$y_k = \begin{bmatrix} 1 & 0 \end{bmatrix} \begin{bmatrix} x_1 \\ x_2 \end{bmatrix}_k + v_k \quad (17)$$

where v_k represents the measurement noise.

If there are n frequencies in the signal S_k , i. e.,

$$S_k = \sum_{i=1}^n A_{i_k} \sin(i\omega_k t_k + \theta_{i_k}), \quad (18)$$

the state-space representation of the signal becomes

$$\begin{bmatrix} x_1 \\ x_2 \\ \vdots \\ x_{2n-1} \\ x_{2n} \end{bmatrix}_{k+1} = \begin{bmatrix} \mathbf{M}_1 & \cdots & 0 \\ \vdots & \ddots & \vdots \\ 0 & \cdots & \mathbf{M}_n \end{bmatrix}_k \begin{bmatrix} x_1 \\ x_2 \\ \vdots \\ x_{2n-1} \\ x_{2n} \end{bmatrix}_k + \begin{bmatrix} \gamma_1 \\ \gamma_2 \\ \vdots \\ \gamma_{2n-1} \\ \gamma_{2n} \end{bmatrix}_k, \quad (19)$$

$$y_k = \begin{bmatrix} 1 & 0 & \cdots & 1 & 0 \end{bmatrix} \begin{bmatrix} x_1 \\ x_2 \\ \vdots \\ x_{2n-1} \\ x_{2n} \end{bmatrix}_k + v_k \quad (20)$$

where

$$\mathbf{M}_i = \begin{bmatrix} \cos(i\omega_k T_s) & \sin(i\omega_k T_s) \\ -\sin(i\omega_k T_s) & \cos(i\omega_k T_s) \end{bmatrix}. \quad (21)$$

The perturbation vector $[\gamma_1 \ \gamma_2 \ \cdots \ \gamma_{2n-1} \ \gamma_{2n}]^T_k$ models amplitude or phase variations of each harmonic component of the signal and its covariance is given by matrix $\mathbf{Q}$, defined by (4). The covariance of the measurement noise v_k is given by $\mathbf{R}$ as defined in (5).

The mathematical model (19)-(21) has the same form as the mathematical model (1)-(2) used in the Kalman filter. Note that this model needs the value of the angular grid frequency that may be subject to deviations from its nominal value. If the frequency considered in the mathematical model differs from the real value, the estimates provided by the filter will not be accurate. It is therefore necessary to identify the grid frequency in real time to update the model used in the Kalman filter. This is accomplished by the method given in next section.

4. Real time frequency identification

The grid frequency identification method proposed here is based on the internal model principle (Francis & Wonham, 1976), in which a stable closed-loop dynamic system is considered, as shown in Fig. 1, with

$$G(z) = \frac{N(z)}{D(z)} \quad (22)$$

proper and coprime and a sinusoidal input signal $R_\omega(z)$, i. e.,

$$R_\omega(z) = \frac{N_R(z)}{D_R(z)} = \frac{z^2 \sin(\omega T_s)}{z^2 - 2 \cos(\omega T_s)z + 1}, \quad (23)$$

if the unstable poles of $R_\omega(z)$ are reproduced by $G(z)$, i. e., $D(z) = D_R(z)$, then

$$\lim_{k \rightarrow \infty} e(kT_s) = \lim_{k \rightarrow \infty} [r_\omega(kT_s) - y_\omega(kT_s)] = 0. \quad (24)$$

Fig. 1. Dynamic system based on the internal model principle

With these considerations, a possible transfer function $G(z)$, for the dynamic system shown in Fig. 1, from which the frequency identifier is derived, is

$$G(z) = K_\omega \frac{z^2 - \cos(\omega T_s)}{z^2 - 2 \cos(\omega T_s)z + 1}. \quad (25)$$

The transfer function (25) can be realized in state-space as

$$\begin{bmatrix} x_{\omega 1} \\ x_{\omega 2} \end{bmatrix}_{k+1} = \begin{bmatrix} 0 & 1 \\ -1 & 2 \cos(\omega_k T_s) \end{bmatrix} \begin{bmatrix} x_{\omega 1} \\ x_{\omega 2} \end{bmatrix}_k + \begin{bmatrix} 0 \\ K_\omega \end{bmatrix} e_k, \quad (26)$$

$$y_{\omega_k} = \begin{bmatrix} -1 & \cos(\omega_k T_s) \end{bmatrix} \begin{bmatrix} x_{\omega 1} \\ x_{\omega 2} \end{bmatrix}_k + K_{\omega} e_k \quad (27)$$

where ω_k , at $k=0$, is initialized with the nominal value of the grid angular frequency. Subsequently, this value will be updated by the identification algorithm that will be developed to satisfy (24). The value of ω_k will be the identified grid frequency.

Let

$$r_{\omega_k} = A_{\omega_k} \sin(\omega_{\omega_k} t_k + \theta_{\omega_k}) \quad (28)$$

be a sinusoidal reference with amplitude A_{ω_k} , angular frequency ω_{ω_k} and phase θ_{ω_k} at time t_k . Now, consider a reference as described by (28) with constant values for A_{ω_k} , ω_{ω_k} and θ_{ω_k} , i. e.,

$$A_{\omega_{k+1}} = A_{\omega_k} = A_{\omega}, \quad (29)$$

$$\omega_{\omega_{k+1}} = \omega_{\omega_k} = \omega_{\omega}, \quad (30)$$

$$\theta_{\omega_{k+1}} = \theta_{\omega_k} = \theta_{\omega} \quad (31)$$

and the model described by (26) and (27) with ω_k constant, i. e.,

$$\omega_{k+1} = \omega_k = \omega. \quad (32)$$

Then, if we define

$$a = \cos(\omega_{\omega} T_s) - \cos(\omega T_s) \quad (33)$$

and

$$b = \sin(\omega_{\omega} T_s), \quad (34)$$

the state $x_{\omega 2_k}$, the output y_{ω_k} and the error e_k will converge to

$$y_{\omega_k} = A_{y_{\omega}} \sin(\omega_{\omega} t_k + \theta_{\omega} + \varphi_{y_{\omega}}), \quad (35)$$

$$x_{\omega 2_k} = \frac{A_{y_{\omega}}}{\sqrt{a^2 + b^2}} \sin(\omega_{\omega} t_k + \theta_{\omega} + \varphi_{x_{\omega 2}}), \quad (36)$$

and

$$e_k = A_e \sin(\omega_{\omega} t_k + \theta_{\omega} + \varphi_{x_{e_{\omega}}}), \quad (37)$$

respectively, where

$$A_{y_{\omega}} = A_{\omega} K_{\omega} \sqrt{\frac{a^2 + b^2}{(2 + K_{\omega})^2 a^2 + K_{\omega}^2 b^2}}, \quad (38)$$

$$A_e = 2A_\omega \sqrt{\frac{a^2}{(2 + K_\omega)^2 a^2 + K_\omega^2 b^2}}, \quad (39)$$

$$\varphi_{y_\omega} = \arctan\left(\frac{2ab}{(2 + K_\omega)a^2 + K_\omega b^2}\right), \quad (40)$$

$$\varphi_{x_{\omega 2}} = -\arctan\left(\frac{K_\omega b}{(2 + K_\omega)a}\right) \quad (41)$$

and

$$\varphi_{x_{e\omega}} = -\arctan\left(\frac{K_\omega ab}{(2 + K_\omega)a^2}\right). \quad (42)$$

When the angular frequency of the driving signal is the same as the frequency considered in the state space representation of $G(z)$, i. e., when $\omega_\omega = \omega$, y_{ω_k} will track the input signal r_{ω_k} by virtue of (35). Hence, from (37), in steady-state, $e_k = 0$. Therefore, the error e_k provides useful information for the identification of the angular frequency ω_ω of the driving signal.

For the proposed discrete model (26)–(27), considering $\omega_\omega \approx \omega$, in steady-state, two orthogonal signals are obtained,

$$y_{\omega_k} \approx A_\omega \sin(\omega_\omega t_k + \theta_\omega) \quad (43)$$

and

$$x_{\omega 2_k} \approx -\frac{A_\omega}{\sin(\omega_\omega)} \cos(\omega_\omega t_k + \theta_\omega). \quad (44)$$

Defining ϕ_k as

$$\phi_k = \omega_\omega t_k + \theta_\omega \quad (45)$$

then, the frequency ω_ω can be obtained by

$$\omega_\omega = \frac{\phi_{k+1} - \phi_k}{T_s} \quad (46)$$

Using (43) and (44) leads to

$$\tan(\phi_k) = \frac{\sin(\omega_\omega t_k + \theta_\omega)}{\cos(\omega_\omega t_k + \theta_\omega)} = \frac{y_{\omega_k}}{-\sin(\omega_\omega T_s) x_{\omega 2_k}}, \quad (47)$$

which gives

$$\phi_k = \arctan(\tan(\phi_k)) \quad (48)$$

To obtain $\tan(\phi_k)$ in (47), we need to know the angular frequency ω_ω of the driving signal, which is unknown. By putting $\omega_\omega \approx \omega$, ω_ω is replaced by ω . Hence,

$$\tan(\phi_k) \approx \frac{y_{\omega_k}}{-\sin(\omega T_s)x_{\omega 2_k}} \quad (49)$$

and

$$\phi_k \approx \arctan\left(\frac{y_{\omega_k}}{-\sin(\omega T_s)x_{\omega 2_k}}\right). \quad (50)$$

Instead of using (46) to obtain the derivative of ϕ_k , (48) is used together with the definition of the continuous derivative of $\arctan$. Then, the continuous values are replaced by the discrete ones available at time t_k , with continuous derivatives approximated by

$$\frac{d}{dt}(\cdot) \approx \frac{(\cdot)_{k+1} - (\cdot)_k}{T_s}. \quad (51)$$

The derivative of $\arctan$ is given by

$$\frac{d}{dt} \arctan[\tan(\phi(t))] = \frac{1}{1 + \tan(\phi(t))^2} \frac{d}{dt} \tan(\phi(t)). \quad (52)$$

which, by replacing $\tan(\phi(t))$ by its value at time t_k as given by (49), using (26)–(27) and re-introducing the subscript of time k , gives an estimate of the frequency ω_ω of the driving signal denoted by $\hat{\omega}_{\omega_k}$,

$$\hat{\omega}_{\omega_k} \approx \omega_k - \frac{1}{T_s} \frac{K_\omega \sin(\omega_k T_s)x_{\omega 2_k} e_k}{[\sin(\omega_k T_s)x_{\omega 2_k}]^2 + [y_{\omega_k}]^2} \quad (53)$$

giving the error $\hat{\omega}_{\omega_k} - \omega_k$,

$$\hat{\omega}_{\omega_k} - \omega_k \approx -\frac{1}{T_s} \frac{K_\omega \sin(\omega_k T_s)x_{\omega 2_k} e_k}{[\sin(\omega_k T_s)x_{\omega 2_k}]^2 + [y_{\omega_k}]^2} = -\frac{1}{T_s} \varepsilon_k \quad (54)$$

where

$$\varepsilon_k = \frac{K_\omega \sin(\omega_k T_s)x_{\omega 2_k} e_k}{[\sin(\omega_k T_s)x_{\omega 2_k}]^2 + [y_{\omega_k}]^2}. \quad (55)$$

Therefore, ω_k can be updated by

$$\frac{\omega_{k+1} - \omega_k}{T_s} = -K_u \frac{1}{T_s} \varepsilon_k \quad (56)$$

giving

$$\omega_{k+1} = \omega_k - K_u \varepsilon_k \quad (57)$$

where K_u is again a scalar value.

Based on (57) the model (26)-(27) is updated. The structure of the identifier is shown in Fig. 2, where the internal model is given by (26)-(27), the error ε_k is given by (55) and the integrator is given by (57).

Fig. 2. Complete structure of the frequency identifier with signals involved.

Since the voltage measurements may be corrupted by measurement noise and harmonics and suffer from voltage sags and swells, the use of these measurements directly as r_{ω_k} may result in undesirable behavior of the frequency identifier. To avoid this, the synchronization signal is used, which is generated by the structures proposed in the next section. As will be shown, these signals are already filtered and normalized.

5. Synchronization methods

5.1 Single-phase synchronization

For single-phase synchronization, it is necessary to generate a signal in phase with the fundamental component of the grid voltage. From (19), it is clear that

$$x_{1k} = A_k \sin(\omega_k t_k + \theta_{1k}) \quad (58)$$

and

$$x_{2k} = A_k \cos(\omega_k t_k + \theta_{1k}), \quad (59)$$

are the orthogonal components of the fundamental voltage phasor of the grid voltage. Its instantaneous phase is

$$\phi_{V1k} = \omega_k t_k + \theta_{1k}. \quad (60)$$

From the Kalman filter described in section 2, with a mathematical model of the signal S_k given by (19)-(21), the estimates of the components of the fundamental voltage phasor $\hat{x}_{1_{k|k-1}}$ and $\hat{x}_{2_{k|k-1}}$ are obtained. Based on these estimates, and assuming $A_k \neq 0$, the sine and cosine functions are given by

$$\sin(\phi_{V1_k}) = \frac{\hat{x}_{1_{k|k-1}}}{A_k} = r_{\omega_k} \quad (61)$$

and

$$\cos(\phi_{V1_k}) = \frac{\hat{x}_{2_{k|k-1}}}{A_k} \quad (62)$$

where

$$A_k = \sqrt{\hat{x}_{1_{k|k-1}}^2 + \hat{x}_{2_{k|k-1}}^2} \quad (63)$$

The angular frequency ω_k needed in the mathematical model used by the Kalman filter is updated by the algorithm described in section 4. The reference signal r_{ω_k} is obtained from (61). This signal contains only the fundamental component of the measured signal and is normalized. The influence of harmonics or amplitude variations of the measured signal is therefore minimized. Fig. 3 shows the proposed single-phase synchronization structure. In this figure, the block termed the Kalman Filter is implemented by (7)–(9). The input of the filter, that is, y_k in (7), is the voltage measurement of the phase of interest. In Fig. 3, the input of the filter is represented by v_k . The Kalman filter will provide the estimates of the harmonics included in the mathematical model (19)–(21) used to describe the signal. Since the interest is on the fundamental component, only the first two estimated states $\hat{x}_{1_{k|k-1}}$ and $\hat{x}_{2_{k|k-1}}$ are used. These estimates are the two orthogonal signals used to obtain the synchronization signals as depicted in Fig. 3.

Fig. 3. Single-phase synchronization structure.

From (61) and (62) the instantaneous phase of the fundamental grid voltage component is found to be

$$\phi_{V1_k} = \arctan \left(\frac{\hat{x}_{1_{k|k-1}}}{\hat{x}_{2_{k|k-1}}} \right) \quad (64)$$

5.2 Three-phase synchronization

In some applications, such as power conditioning equipment (Campos et al., 1994; Song & Nam, 2000), distributed generation (Karimi-Ghartemani & Iravani, 2004; Blaabjerg et al., 2006), PWM rectifiers (De Camargo & Pinheiro, 2006) among others, it is desirable that the synchronization method be able to provide synchronism signals in phase with the positive sequence of the fundamental component of the grid voltages.

Given the fundamental phase voltages $v_{a_k}^f$, $v_{b_k}^f$ and $v_{c_k}^f$, the positive sequence components can be obtained through (Fortescue, 1918)

$$\begin{bmatrix} v_a^+ \\ v_b^+ \\ v_c^+ \end{bmatrix}_k = \frac{1}{3} \begin{bmatrix} 1 & \alpha & \alpha^2 \\ \alpha^2 & 1 & \alpha \\ \alpha & \alpha^2 & 1 \end{bmatrix} \begin{bmatrix} v_a^f \\ v_b^f \\ v_c^f \end{bmatrix}_k \quad (65)$$

where $\alpha = e^{j120^\circ}$. Considering $e^{\pm j120^\circ} = -\left(\frac{1}{2}\right) \pm \left(\frac{\sqrt{3}}{2}\right) e^{j90^\circ}$ and defining S_{90} as the 90° phase shift operator, i. e., $S_{90} = e^{j90^\circ}$, (65) can be rewritten as

$$\begin{aligned} v_{a_k}^+ &= \frac{1}{3} v_{a_k}^f - \frac{1}{6} (v_{b_k}^f + v_{c_k}^f) + \frac{\sqrt{3}}{6} S_{90} (v_{b_k}^f - v_{c_k}^f), \\ v_{b_k}^+ &= -v_{a_k}^+ - v_{c_k}^+, \\ v_{c_k}^+ &= \frac{1}{3} v_{c_k}^f - \frac{1}{6} (v_{a_k}^f + v_{b_k}^f) + \frac{\sqrt{3}}{6} S_{90} (v_{a_k}^f - v_{b_k}^f) \end{aligned} \quad (66)$$

The values of $v_{a_k}^f$, $v_{b_k}^f$, $v_{c_k}^f$ and their orthogonal components $S_{90}(v_{a_k}^f)$, $S_{90}(v_{b_k}^f)$ and $S_{90}(v_{c_k}^f)$ are obtained directly from the Kalman filter due to (58) and (59). That is, $v_{a_k}^f = \hat{x}_{1_{k|k-1}}^a$, $v_{b_k}^f = \hat{x}_{1_{k|k-1}}^b$, $v_{c_k}^f = \hat{x}_{1_{k|k-1}}^c$ and $S_{90}(v_{a_k}^f) = \hat{x}_{2_{k|k-1}}^a$, $S_{90}(v_{b_k}^f) = \hat{x}_{2_{k|k-1}}^b$, $S_{90}(v_{c_k}^f) = \hat{x}_{2_{k|k-1}}^c$, where the superscripts a , b and c indicate the filter associated to each phase. This avoids the need for additional filters to provide the phase shift required in the fundamental component to obtain the orthogonal components of the voltages. To obtain the synchronism signals, the positive sequence components are represented in the stationary reference frame $\alpha\beta$:

$$\begin{bmatrix} v_\alpha^+ \\ v_\beta^+ \end{bmatrix}_k = \frac{2}{3} \begin{bmatrix} 1 & -\frac{1}{2} & -\frac{1}{2} \\ 0 & -\frac{\sqrt{3}}{2} & \frac{\sqrt{3}}{2} \end{bmatrix} \begin{bmatrix} v_a^+ \\ v_b^+ \\ v_c^+ \end{bmatrix}_k \quad (67)$$

To simplify the transforms (66) and (67), they can be combined as

$$\mathbf{v}_{\alpha\beta}^+ = \mathbf{T}_1 \mathbf{v}_{abc_k}^f + \mathbf{T}_2 S_{90} \mathbf{v}_{abc_k}^f \quad (68)$$

where

$$\mathbf{v}_{\alpha\beta_k}^+ = \begin{bmatrix} v_\alpha^+ \\ v_\beta^+ \end{bmatrix}_k, \quad \mathbf{v}_{abc_k}^f = \begin{bmatrix} v_a^f \\ v_b^f \\ v_c^f \end{bmatrix}_k \quad (69)$$

$$\mathbf{T}_1 = \frac{2}{3} \begin{bmatrix} 1/2 & -1/4 & -1/4 \\ 0 & -\sqrt{3}/4 & \sqrt{3}/4 \end{bmatrix}, \quad (70)$$

and

$$\mathbf{T}_2 = \frac{2}{3} \begin{bmatrix} 0 & \sqrt{3}/4 & -\sqrt{3}/4 \\ 1/2 & -1/4 & -1/4 \end{bmatrix}. \quad (71)$$

Therefore, considering $\|\mathbf{v}_{\alpha\beta}^+\| \neq 0$ the synchronism signals are given by

$$\sin(\phi_{v_{a_k}}^+) = \frac{v_{\alpha_k}^+}{\|\mathbf{v}_{\alpha\beta_k}^+\|} = r_{\omega_k} \quad (72)$$

and

$$\cos(\phi_{v_{a_k}}^+) = \frac{v_{\beta_k}^+}{\|\mathbf{v}_{\alpha\beta_k}^+\|} \quad (73)$$

where

$$\|\mathbf{v}_{\alpha\beta_k}^+\| = \sqrt{(v_{\alpha_k}^+)^2 + (v_{\beta_k}^+)^2}. \quad (74)$$

The angular frequency in the mathematical model used by the Kalman filter is updated again by the algorithm set out in section 4. The reference signal r_{ω_k} is obtained from (72).

Fig. 4 shows the proposed three-phase synchronization method. Similar to the single-phase case, the signals v_{a_k} , v_{b_k} and v_{c_k} , in Fig. 4, are the inputs of three Kalman filters used to decompose the grid voltages of each phase in the harmonic components considered in the signal model. From each filter, the first two orthogonal estimated states are used by the positive sequence extractor block, i. e., $v_{a_k}^f$, $v_{b_k}^f$, $v_{c_k}^f$ and its orthogonal components $S_{90}(v_{a_k}^f)$, $S_{90}(v_{b_k}^f)$ and $S_{90}(v_{c_k}^f)$. Note that to reduce the processing time, the positive sequence extractor and abc to $\alpha\beta$ blocks are combined as shown by (68).

Fig. 4. Three-phase synchronization structure.

The instantaneous phase can be obtained from (72) and (73),

$$\phi_{v_{a_k}}^+ = \arctan \left(\frac{v_{a_k}^+}{v_{\beta_k}^+} \right) \quad (75)$$

while the amplitude of the positive sequence component is

$$A_k^+ = \left\| \mathbf{v}_{a\beta_k}^+ \right\|. \quad (76)$$

6. Voltage analysis

In Fig. 4, which shows the structure of the three-phase KF-PLL, it can be observed that some information about the grid voltages can be directly obtained, for instance, fundamental components, harmonics, symmetrical components and frequency. This indicates that the KF-PLL can also be used for purposes of voltage analysis. This section describes how the information provided by the different blocks of the KF-PLL can be used for this purpose.

The three-phase KF-PLL uses three Kalman filters in its first block. Each filter is associated to one of the phase voltages. Based on these filters, it is possible to optimally extract the harmonics of each phase voltage and their orthogonal components. Hence, the amplitude of the considered harmonic component can be obtained straightforwardly as shown by (58), (59) and (63). In this case, the fundamental component was considered. Obviously, it can be extended to any harmonic component considered in the model (19)-(21).

Based on the harmonic components extracted by the Kalman filters, the total harmonic distortion (THD) can also be evaluated in real time, that is,

$$THD_k = \frac{\sqrt{\sum_{i=2}^n A_{i_k}^2}}{A_k} \quad (77)$$

where A_k is the amplitude of the fundamental component and A_{i_k} is the amplitude of the i -th harmonic component.

The detection of the symmetrical components is important for purposes of monitoring unbalance. In the KF-PLL, the positive sequence is promptly available. To measure the degree of unbalance, the negative and possibly the zero sequence components must be also detected. The zero sequence component can be obtained from

$$v_k^0 = \frac{1}{3} (v_{a_k}^f + v_{b_k}^f + v_{c_k}^f), \quad (78)$$

while its magnitude can be evaluated from

$$A_k^0 = \sqrt{(v_k^0)^2 + (S_{90} v_k^0)^2} \quad (79)$$

where

$$S_{90}v_k^0 = \frac{1}{3}(S_{90}v_{a_k}^f + S_{90}v_{b_k}^f + S_{90}v_{c_k}^f). \quad (80)$$

The negative sequence components are obtained straightforwardly from

$$v_{i_k}^- = v_{i_k}^f - v_{i_k}^+ - v_k^0, \quad i = a, b, c, \quad (81)$$

while its magnitude is given by

$$A_k^- = \sqrt{\frac{2}{3} \left((v_{a_k}^-)^2 + (v_{b_k}^-)^2 + (v_{c_k}^-)^2 \right)}. \quad (82)$$

Note that representing the negative sequence components in the $\alpha\beta$ reference frame, that is,

$$\begin{bmatrix} v_{\alpha}^- \\ v_{\beta}^- \end{bmatrix}_k = \frac{2}{3} \begin{bmatrix} 1 & -1/2 & -1/2 \\ 0 & \sqrt{3}/2 & \sqrt{3}/2 \end{bmatrix} \begin{bmatrix} v_a^- \\ v_b^- \\ v_c^- \end{bmatrix}_k, \quad (83)$$

the synchronization signals with these components can be obtained by

$$\sin(\phi_{V_{a_k}}^-) = \frac{v_{a_k}^-}{\|\mathbf{v}_{\alpha\beta_k}^-\|}, \quad \cos(\phi_{V_{a_k}}^-) = \frac{v_{\beta_k}^-}{\|\mathbf{v}_{\alpha\beta_k}^-\|} \quad (84)$$

where

$$\|\mathbf{v}_{\alpha\beta_k}^-\| = A_k^- = \sqrt{(v_{a_k}^-)^2 + (v_{\beta_k}^-)^2}. \quad (85)$$

Hence, the instantaneous phase of the negative sequence component is

$$\phi_{V_{a_k}}^- = \arctan\left(\frac{v_{a_k}^-}{v_{\beta_k}^-}\right). \quad (86)$$

Similarly,

$$\sin(\phi_{V_k}^0) = \frac{v_k^0}{A_k^0}, \quad \cos(\phi_{V_{a_k}}^-) = \frac{S_{90}v_k^0}{A_k^0} \quad (87)$$

And the instantaneous phase of the zero sequence component is given by

$$\phi_{V_k}^0 = \arctan\left(\frac{v_k^0}{S_{90}v_k^0}\right). \quad (88)$$

Further details on voltage analysis based on Kalman filter can be found in (Cardoso et. al., 2007).

7. Digital implementation

This section describes the digital implementation of the synchronization methods in a 32 bits fixed-point DSP (TI-TMS320F2812). Because of the finite word length and precision of the device, the IQmath library (Texas Instruments, 2002) was used to improve the performance of the algorithms. To determine the sampling frequency, two factors must be considered: calculation time and the sampling frequency usually used in the power electronic apparatus. If neither the calculation time nor the equipment sampling frequency impose restrictions, higher sampling frequencies will provide better results. The sampling frequency used here is 10.5 kHz.

The mathematical model used in the Kalman filter incorporates the fundamental, 3rd, 5th, 7th and 11th harmonics. The covariance of the measurement noise is set to $\mathbf{R} = 200V^2$ while the covariance of the process noise is set to $\mathbf{Q} = 0.05I_{10 \times 10} V^2$. In fact, in practice, both matrices $\mathbf{Q}$ and $\mathbf{R}$ can be identified by using whitening techniques as presented in (Mehra, 1970; Cardoso et al., 2005).

To design the transfer function gain K_ω , see (25), the natural frequency is set equal to the nominal angular frequency of the grid, i. e., $\omega_n = \omega = 377 \text{ rad/s}$ and a damping coefficient $\xi = 0.707$ is used. Therefore, from the well known relationships (Ogata, 1994)

$$|z| = e^{-T_s \xi \omega_n} \quad (89)$$

and

$$\angle z = T_s \omega_n \sqrt{1 - \xi^2} \text{ (rad)} \quad (90)$$

replacing the values of ω_n and ξ by those defined for them gives the roots of the closed loop characteristic equation, i. e.,

$$z = 0.975 \pm j0.025. \quad (91)$$

From (91) and the closed loop characteristic equation, solving for K_ω we have $K_\omega = 0.052$. The gain K_u is responsible for the speed of convergence of the frequency identifier. For fast convergence, K_u must have a large value. However, a high value for K_u may lead to an undesirable behavior of the identifier. In the following experiments $K_u = 20$. This gain provides a satisfactory performance for the integrator.

When implementing the Kalman filter, it is necessary to evaluate the Kalman gain K_k , given by (8), for which the covariance matrix (9) must be computed at every sampling time k . Since the standards (IEC 60034, 1996; IEC 61000-2-2, 2001; IEEE Std C37.106, 2003) limit the range of frequency deviation in the grid, a fixed Kalman gain can be evaluated at the nominal grid frequency. This simplification imposes a negligible reduction in the performance of the Kalman filter when compared with the use of the Kalman gain evaluated for the actual grid frequency, as will be shown below.

Considering $f = 60 \text{ Hz}$ and based on the values $\mathbf{Q} = 0.05I_{10 \times 10} V^2$ and $\mathbf{R} = 200V^2$, previously defined, the following steady-state Kalman filter gain is obtained

$$\mathbf{K}_{\infty 60} = \begin{bmatrix} 21.1726 & -0.0848 & 21.1721 & -0.1728 & 21.1727 & \cdots \\ \cdots & 0.0693 & 21.1161 & 1.5481 & 21.0486 & -2.2893 \end{bmatrix}^T \times 10^{-3}. \quad (92)$$

Based on this gain, Fig. 5 shows the frequency response of the Kalman filter states $\hat{x}_1$ and $\hat{x}_2$. The proposed synchronization schemes strongly reject the harmonics at the frequencies used in the mathematical model. At the fundamental frequency, the gains equal unity and the difference in phase is 0° and -90° for the states $\hat{x}_1$ and $\hat{x}_2$, respectively. Figs. 6a and 6b present the errors in magnitude, in dB, and in phase, in degrees, that arise when fixed gains are used. When fixed gains are evaluated for the nominal grid frequency, i. e., $f = 60\text{ Hz}$, both errors, in magnitude and phase, are negligible if the actual grid frequency is updated in the mathematical model of the filter.

Fig. 5. Frequency response of the Kalman filter considering $f = 60\text{ Hz}$.

a) Error introduced by using fixed Kalman gains but considering $f = 57\text{ Hz}$ in the mathematical model of the Kalman filter. b) Error introduced by using fixed Kalman gains but considering $f = 63\text{ Hz}$ in the mathematical model of the Kalman filter.

Fig. 6. Frequency response errors for different conditions of operation of the Kalman filter.

8. Experimental results

The single and three-phase synchronization methods were implemented in a fixed point DSP (TI-TMS320F2812) to evaluate their performance in real time. The Kalman gain used and sampling frequency are the same as described in section 7. Fig. 7a and Fig. 7b depict the synchronization signals obtained with the proposed single and the three-phase KF-PLLs

superimposed with the distorted grid voltage ($THD = 5.8\%$). Fig. 7c and Fig. 7d show the synchronization signals for a sinusoidal grid voltage. The good behavior of both proposed structures can be noted, even when voltage waveforms are distorted.

a) Single-phase under distorted grid voltages ($THD=5.8\%$)

b) Three-phase under distorted grid voltages ($THD=5.8\%$)

c) Single-phase under sinusoidal grid voltages

d) Three-phase under sinusoidal grid voltages

Fig. 7. Synchronization signals obtained.

The use of the KF-PLL for purposes of voltage analysis is exemplified in the following set of experimental results. Again, the results are based on a fixed point DSP (TI-TMS320F2812) implementation. The voltages are composed of a 220 V fundamental component and the following harmonics are present: 5th, 7th, and 11th, with amplitudes given by 0.3 p.u., 0.15 p.u. and 0.09 p.u., respectively, referring to the fundamental peak value. Therefore, the total harmonic distortion of the voltages is $THD = 34.7\%$. At $t = 0.0832\text{ s}$ a voltage drop of 30% occurs in all phases. Additionally, an unbalance of 50% is considered in phase c. The KF-PLL was tuned considering: $\mathbf{Q} = 0.01\mathbf{I}_{10 \times 10} V^2$, $\mathbf{R} = 20V^2$, $Ku = 20$ and $Kw = 0.052$.

Fig. 8a shows the measured grid voltages while Fig 8b depicts the extracted fundamental components of each phase with their amplitudes. Note that the fundamental components are adequately detected. The same occurs with the peak values. The convergence of the signals is fast and occurs in less than one cycle.

Fig. 9 presents the extraction of the harmonics in the measured signal with their amplitudes evaluated in real time. Note that the non-existent 3rd harmonic is also correctly detected.

Fig. 8. Measured grid voltages and fundamental extraction.

Fig. 9. Harmonic decomposition and amplitude detection.

The detection of the symmetrical components is depicted in Fig. 10a. Until $t=0.0832s$ the grid voltages are balanced and the negative and zero sequence are zero. After $t=0.0832s$, the voltages are unbalanced and the proposed method detects the presence of negative and zero sequences adequately. The amplitude of the positive, negative and zero sequences are also correctly identified.

Fig. 10b shows the generation of the synchronization signals with the negative sequence components of the fundamental voltages. It also presents the associated instantaneous phase. Similar results can also be obtained with the zero sequence component or any harmonic signal of interest.

Finally, Fig. 11 depicts the THD of the phase a voltage, evaluated in real time. It also shows the identified grid frequency, which due to the normalized signal used to drive the identifier, is practically immune to transients in grid voltages.

Fig. 10. Symmetrical components and synchronism signals.

Fig. 11. THD and identified frequency.

9. Conclusions

This chapter presented a description of how the Kalman filter can be used to obtain the synchronization signals with the grid voltages as well as how it can also be helpful for voltage analysis. As for synchronization, the described methods are capable of dealing with signals corrupted by harmonics and measurement noise. For three-phase systems the method also considers voltage imbalance.

To deal with voltage frequency variations, the fundamental grid frequency is identified in real time to update the Kalman filter model. It was shown that for frequency deviations within the limits allowed by several standards, fixed Kalman gains can be used, which simplifies digital implementation. The formulation of the proposed synchronization schemes deals explicitly with the following phenomena that can occur in a real system: presence of harmonics, voltage transients, measurement noise, voltage imbalance and frequency deviation.

As mentioned, the synchronization methods can also provide information about the grid voltages such as harmonic analysis, amplitude detection, instantaneous phase, extraction of symmetrical components and frequency, useful for the analysis of power quality.

The experimental results show that the proposed synchronization methods can be implemented without great difficulty in a fixed-point DSP. The implementation based on fixed Kalman gains simplifies the DSP implementation, and it was shown that the effect on performance of the fixed gains is small.

10. References

- BLAABJERG, F.; TEODORESCU, R.; LISERRE, M.; TIMBUS, A. V. (2006). Overview of control and grid synchronization for distributed power generation systems. *IEEE Transactions on Industrial Electronics*, Vol. 53, No. 5, October 2006, pp. 1398-1409
- BOUTAYEB, M., RAFARALAHY, H., DAROUACH, M. (1997). Convergence analysis of the extended Kalman filter used as an observer for nonlinear deterministic discrete-time systems, *IEEE Transactions on Automatic Control*, Vol. 42, No. 4, April 1997, pp. 581-586
- BOUTAYEB, M., AUBRY, D. (1999). A strong tracking extended Kalman observer for nonlinear discrete-time systems, *IEEE Transactions on Automatic Control*, Vol. 44, No. 8, August 1999, pp. 1550-1556
- BROWN, R. G. (1992) *Introduction to Random Signals and Applied Kalman Filtering*, John Wiley & Sons, New York
- BROWN, L. J., ZHANG, Q. (2004). Periodic disturbance cancellation with uncertain frequency, *Automatica*, Vol. 40, No. 4, April 2004, pp. 631-637
- CAMPOS, A., JOOS, G., ZIOGAS, P. D., LINDSAY, J. F. (1994). Analysis and design of a series voltage unbalance compensator based on a three-phase VSI operating with unbalance switching functions, *IEEE Transactions on Power Electronics*, Vol. 9, No. 3, May 1994, pp. 269-274
- CARDOSO, R., CÂMARA, H. T., GRÜNDLING, H. A. (2005). Sensorless induction motor control using low cost electrical sensors, *Proceedings of 36th IEEE Power Electronics Specialists Conference*, pp. 1600-1606, June 2005, IEEE, Recife
- CARDOSO, R., DE CAMARGO, R. F., PINHEIRO, H., GRÜNDLING, H. A. (2006). Kalman filter based synchronization methods, *Proceedings of 37th IEEE Power Electronics Specialists Conference*, pp. 1935-1941, June 2006, IEEE, Jeju
- CARDOSO, R.; KANIESKI, J. M.; PINHEIRO, H. & GRÜNDLING, H. A. (2007). Power quality evaluation based on optimum filtering theory for time-varying frequencies, *Proceedings of 9th Brazilian Power Electronics Conference*, pp. 462-467, September-October 2007, Sobraep, Blumenau
- CARDOSO, R.; DE CAMARGO, R. F.; PINHEIRO, H. & GRÜNDLING, H. A. (2008). Kalman filter based synchronization methods. *IET Generation, Transmission & Distribution*, Vol. 2, No. 4, July 2008, pp. 542-555
- CHUNG, S.-K. (2000). A phase tracking system for three phase utility interface inverters. *IEEE Transactions on Power Electronics*, Vol. 15, No. 3, May 2000, pp. 431-438
- CHRISTIANSEN, G. S. (1994). Modelling of a PRML timing loop as a Kalman filter, *Proceedings of IEEE Global Telecommunications Conference*, pp. 1157-1161, November-December 1994, IEEE, San Francisco
- DE CAMARGO, R. F., PINHEIRO, H. (2006). Synchronization method for three-phase PWM converters under unbalance and distorted grid. *IEE Proceedings Electric Power Applications*, Vol. 153, No. 5, September 2006, pp. 763-772
- DRIESSEN, P. F. (1994). DPLL bit synchronizer with rapid acquisition using adaptive Kalman filtering techniques. *IEEE Transactions on Communications*, Vol. 42, No. 9, September 1994, pp. 2673-2675

- FORTESCUE, C. L. (1918). Method of symmetrical coordinates applied to the solution of polyphase networks. *Trans. AIEE*, Vol. 37, 1918, pp. 1027-1140
- FRANCIS, B. A., WONHAM, W. M. (1976). The internal model principle of control theory, *Automatica*, Vol. 12, No. 5, 1976, pp. 457-465
- GELB, A., KASPER JR., J. F., NASH JR., R. A., PRICE, C. F., SUTHERLAND JR. A. A. (1996). *Applied Optimal Estimation*, M.I.T. Press, Cambridge
- GUPTA, S. C. (1975). Phase-locked loops. *Proceedings of the IEEE*, Vol. 63, 1975, pp. 291-306
- HSIEH, G.-C., HUNG, J. C. (1996). Phase-locked loop techniques-a survey. *IEEE Transactions on Industrial Electronics*, Vol. 43, No. 6, December 1996, pp. 609-615
- IZADI, M. H., LEUNG, B. (2002). PLL-based frequency discriminator using the loop filter as an estimator. *IEEE Transactions on Circuit and Systems-II: Analog and Digital Signal Processing*, Vol. 49, No. 11, November 2002, pp. 721-727
- IEC 60034 (1996). *Rotating electrical machines part 3: Specific requirements for turbine-type synchronous machines*, IEC
- IEC 61000-2-2 (2001). *Electromagnetic compatibility (EMC) part 2-2: Environment-Compatibility levels for low frequency conducted disturbances and signaling in public low-voltage power supply systems*, IEC
- IEEE Std C37.106 (2003). *IEEE guide for abnormal frequency protection for power generating plants*, IEEE
- KALMAN, R. E. (1960). A new approach to linear filtering and prediction problems. *Journal of Basic Engineering*, Series 82D, March 1960, pp. 35-45
- KARIMI-GHARTEMANI, M., IRAVANI, M. R. (2004). A method for synchronization of power electronic converters in polluted and variable-frequency environments. *IEEE Transactions on Power Systems*, Vol. 19, No. 3, August 2004, pp. 1263-1270
- KAURA, V., BLASKO, V. (1997). Operation of a phase locked loop system under distorted utility conditions. *IEEE Transactions on Industry Applications*, Vol. 33, No. 1, January/February 1997, pp. 58-63
- MAYBECK, P. S. (1979). *Stochastic Models, Estimation and Control-Vol. 1*, Academic Press, New York
- MEHRA, R. K. (1970). On the identification of variances and adaptive Kalman filtering. *IEEE Transactions on Automatic Control*, Vol. AC-15, No. 3, April 1970, pp. 175-184
- OGATA, K. (1994). *Discrete-Time Control Systems*, Prentice-Hall, Upper Saddle River
- PATAPOUNIAN, A. (1999). On phase-locked loops and Kalman filters. *IEEE Transactions on Communications*, Vol. 47, No. 5, May 1999, pp. 670-672
- RODRÍGUEZ, P., LUNA, A., CIOBOTARU, M., TEODORESCU, R., BLAABJERG, F. (2006). Advanced grid synchronization system for power converters under unbalanced and distorted operating conditions, *Proceedings of Annual Conference of the IEEE Industrial Electronics Society*, pp. 5173-5178, November 2006, IEEE, Paris
- SONG, H.-S., NAM, K. (2000). Instantaneous phase-angle estimation algorithm under unbalanced voltage-sag conditions. *IEE Proc. Gener. Transm. Distrib.*, Vol. 147, No. 6, November 2000, pp. 409-415
- SVENSSON, J. (2001). Synchronization methods for grid-connected voltage source converters, *IEE Proc. Gener. Transm. Distrib.*, Vol. 148, No. 3, May 2001, pp. 229-235
- TEXAS INSTRUMENTS (2002). *IQ Math Library-Module User's Guide-C28x Foundation Software*, TI, Dallas
- TIMBUS, A. V., BLAABJERG, F., TEODORESCU, R., LISERRE, M., RODRIGUEZ, P. (2006). PLL algorithm for power generation systems robust to grid voltage faults, *Proceedings of 37th IEEE Power Electronics Specialists Conference*, pp. 1360-1366, June 2006, IEEE, Jeju
- ZHAO, Z., BROWN L. (2004). Fast estimation of power system frequency using adaptive internal-model control technique, *Proceedings of 43rd IEEE Conference on Decision and Control*, pp. 845-850, December 2004, Bahamas

Kalman Filter Recent Advances and Applications

Edited by Victor M. Moreno and Alberto Pigazo

ISBN 978-953-307-000-1

Hard cover, 584 pages

Publisher InTech

Published online 01, April, 2009

Published in print edition April, 2009

The aim of this book is to provide an overview of recent developments in Kalman filter theory and their applications in engineering and scientific fields. The book is divided into 24 chapters and organized in five blocks corresponding to recent advances in Kalman filtering theory, applications in medical and biological sciences, tracking and positioning systems, electrical engineering and, finally, industrial processes and communication networks.

How to reference

In order to correctly reference this scholarly work, feel free to copy and paste the following:

Rafael Cardoso and Hilton Abílio Gründling (2009). Grid Synchronization and Voltage Analysis Based on the Kalman Filter, Kalman Filter Recent Advances and Applications, Victor M. Moreno and Alberto Pigazo (Ed.), ISBN: 978-953-307-000-1, InTech, Available from:
http://www.intechopen.com/books/kalman_filter_recent_advances_and_applications/grid_synchronization_and_voltage_analysis_based_on_the_kalman_filter

INTECH
open science | open minds

InTech Europe

University Campus STeP Ri
Slavka Krautzeka 83/A
51000 Rijeka, Croatia
Phone: +385 (51) 770 447
Fax: +385 (51) 686 166
www.intechopen.com

InTech China

Unit 405, Office Block, Hotel Equatorial Shanghai
No.65, Yan An Road (West), Shanghai, 200040, China
中国上海市延安西路65号上海国际贵都大饭店办公楼405单元
Phone: +86-21-62489820
Fax: +86-21-62489821

© 2009 The Author(s). Licensee IntechOpen. This chapter is distributed under the terms of the [Creative Commons Attribution-NonCommercial-ShareAlike-3.0 License](#), which permits use, distribution and reproduction for non-commercial purposes, provided the original is properly cited and derivative works building on this content are distributed under the same license.